

Building Assessment Referral Response

Application Number:	DA2023/1162
Proposed Development:	Alterations and additions to a dwelling house including secondary dwelling
Date:	15/01/2024
To:	Simon Ferguson Tuor
Land to be developed (Address):	Lot 74 DP 25329 , 14 Marinna Road ELANORA HEIGHTS NSW 2101

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Change of Building Class

The proposed modifications to the existing building to include a secondary dwelling will result in a change of classification to a Class 2 building and is required to be upgraded to comply with Parts C &

F (specifically 'fire resistance' and 'sound transmission and insulation ratings') of the National Construction Code - Volume One - Building Code of Australia.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for fire safety, building occupant safety and amenity.