

## Environmental Health Referral Response - unsewered land

<b>Application Number:</b>	DA2023/1832
<b>Proposed Development:</b>	Construction of a dwelling house and detached studio
<b>Date:</b>	11/01/2024
<b>Responsible Officer</b>	Stephanie Gelder
<b>Land to be developed (Address):</b>	Lot 5 DP 590990 , 5 Portions Lovett Bay LOVETT BAY NSW 2105 Lot LIC 301874 , 5 Portions Lovett Bay LOVETT BAY NSW 2105

### Reasons for referral

This application seeks consent for development upon unsewered land.

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

### Officer comments

#### General Comments

This application is seeking consent for the construction of a new dwelling and a studio. A wastewater report has been prepared and has recommended an AWTS with absorption beds. Environmental Health recommends approval subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Environmental Health and Protection Conditions:

#### **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

#### Wastewater disposal areas

Proposed works shall not impact on any wastewater disposal (Land Application Areas) building materials and equipment shall not be stored within the wastewater disposal areas on site.

Reason: To protect land and infrastructure in the wastewater disposal area from damage and failure.

#### **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

#### Wastewater system compliance

All recommendations and required works as contained within the report by Broadcrest Consulting Pty Ltd dated September 2023, reference 3258-WW-A-01, being implemented.

Details demonstrating compliance are to be submitted to the Principal Certifier.

Reason: To ensure the wastewater disposal system is compliant and will not create a risk to public health.

### **Wastewater system installation approved by a suitably qualified person**

Prior to the release of the Occupation Certificate evidence must be supplied to the Principal Certifier from a suitably qualified person that the on-site wastewater management system has been installed according to requirements listed in the certificate of accreditation for the wastewater system and wastewater report by Broadcrest Consulting Pty Ltd referenced as 3258-WW-A-01 and dated September 2023.

Reason: To ensure the wastewater system has been installed correctly to minimise the potential for harm.

### **Specification of wastewater system to be installed**

The NSW Health certificate of accreditation of the Aerated Wastewater Treatment System (AWTS) to be installed must be provided to the Principal Certifier and Council for its records prior to the release of the Construction Certificate.

Reason: To ensure the wastewater system to be installed is accredited for domestic use.

### **Wastewater System Approval to Operate**

Prior to the issuing of an Occupation Certificate, a copy of a s68 (Local Government Act 1993) approval to operate the wastewater system, and the wastewater system must be activated and effectively operating to the satisfaction of the Principal Certifier.

Details demonstrating compliance are to be submitted to the Principal Certifier.

Reason: To ensure the premises are maintained in an appropriate manner in perpetuity.