

Landscape Referral Response

| Application Number: | DA2021/0262 |
|---------------------------------|--|
| Date: | 20/04/2021 |
| Responsible Officer: | Clare Costanzo |
| Land to be developed (Address): | Lot 1 DP 81702 , 81 Sydney Road MANLY NSW 2095 |

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The development application is for remedial works to an existing garage.

Council's Landscape Referral section have assessed the application against the Manly Local Environment Plan, and against the following landscape controls of Manly DCP 2013 (but not limited to):

- section 3: General Principles of Development, including but not limited to clauses 3.3.1 Landscape Design, and 3.3.2 Preservation of Trees and Bushland Vegetation,
- section 4: Development Controls and Development Types, including but not limited to clauses 4.1.5 Open Space and Landscaping.

The proposed works require the removal of an existing Phoenix Palm located at the base of the existing garage. The Phoenix Palm is an Exempt Species under the DCP by species type, is located within 2 metres of an approved structure, and does not require Council consent for removal. All other vegetation is proposed for retention.

Landscape Referral raise no objections.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Tree and Vegetation Protection

- a) Existing trees and vegetation shall be retained and protected, including:
- i) all trees and vegetation within the site, excluding exempt trees (*) and vegetation under the relevant planning instruments of legislation,

DA2021/0262 Page 1 of 2



- ii) all trees and vegetation located on adjoining properties,
- iii) all road reserve trees and vegetation.
- (*) the existing Phoenix Palm is listed as an Exempt Species.
- b) Tree protection shall be undertaken as follows:
- i) tree protection shall be in accordance with Australian Standard 4970-2009 Protection of Trees on Development Sites,
- ii) existing ground levels shall be maintained within the tree protection zone of trees to be retained, unless authorised by an Arborist with minimum AQF Level 5 in arboriculture,
- iii) removal of existing tree roots at or >25mm (\emptyset) diameter is not permitted without consultation with an Arborist with minimum AQF Level 5 in arboriculture,
- iv) no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,
- v) structures are to bridge tree roots at or >25mm (Ø) diameter unless directed by an Arborist with minimum AQF Level 5 in arboriculture on site,
- vi) excavation for stormwater lines and all other utility services is not permitted within the tree protection zone, without consultation with an Arborist with minimum AQF Level 5 in arboriculture including advice on root protection measures.
- vii) should either or all of v) or vi) occur during site establishment and construction works, an Arborist with minimum AQF Level 5 in arboriculture shall provide recommendations for tree protection measures. Details including photographic evidence of works undertaken shall be submitted by the Arborist to the Certifying Authority,
- viii) any temporary access to, or location of scaffolding within the tree protection zone of a protected tree or any other tree to be retained during the construction works is to be undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of Australian Standard 4970-2009 Protection of Trees on Development Sites.
- ix) the activities listed in section 4.2 of Australian Standard 4970-2009 Protection of Trees on Development Sites shall not occur within the tree protection zone of any tree on the lot or any tree on an adjoining site,
- x) tree pruning from within the site to enable approved works shall not exceed 10% of any tree canopy, and shall be in accordance with Australian Standard 4373-2007 Pruning of Amenity Trees,
- xi) the tree protection measures specified in this clause must: i) be in place before work commences on the site, and ii) be maintained in good condition during the construction period, and iii) remain in place for the duration of the construction works.

Note: All street trees within the road verge and trees within private property are protected under Northern Beaches Council development control plans, except where Council's written consent for removal has been obtained. The felling, lopping, topping, ringbarking, or removal of any tree(s) is prohibited.

Reason: Tree and vegetation protection.

DA2021/0262 Page 2 of 2