

Date: 23 September 2021

Ref: 33306Zlet

Ms Jill Morrison

Email: [jillpmorrison@gmail.com](mailto:jillpmorrison@gmail.com)

**GEOTECHNICAL ENDORSEMENT  
SECTION 4.55 AMENDMENT  
287 HUDSON PARADE, CLAREVILLE, NSW**

We confirm that we prepared a geotechnical stability assessment report (Ref: 33306Zrpt, dated 28 October 2020) for the proposed alterations and additions at the above site. We also signed off Form 1 and 1a which accompanied the DA.

A Section 4.55 Amendment is now proposed.

In this regard we have reviewed architectural drawings (A0.02, A0.03, A1.01, A01.03, A02.02, A03.01 and A03.02) prepared by Dalman. We have also reviewed hydraulic drawings (130101-D101<sup>D</sup>, D102<sup>D</sup>, D103<sup>D</sup> and D104<sup>D</sup>) prepared by NB Consulting Engineers.

The architectural drawings indicate that the proposed amendments comprise internal reconfigurations and as such there are no stability or other geotechnical impacts on the site.

The hydraulic drawings show the stormwater directed to the creek along the east. This is in accordance with the recommendations of our report, and from a geotechnical perspective is a superior stormwater disposal solution compared to discharging over the hillside or piping down to the kerb of Hudson Parade.

The above amendments/proposals which are associated with the Section 4.55 Amendment will have no impact on the risk levels outlined in our report, and can, from a geotechnical point of view, proceed, provided that the recommendations presented in our report are adopted in their entirety.





---

Should you require any further information regarding the above, please do not hesitate to contact the undersigned.

Yours faithfully  
For and on behalf of  
JK GEOTECHNICS

A handwritten signature in dark ink, appearing to read 'Agi Zenon'.

**Agi Zenon**  
Principal Consultant | Geotechnical Engineer