BASIX[°]Certificate

Building Sustainability Index www.basix.nsw.gov.au

Alterations and Additions

Certificate number: A336749 05

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Alterations and Additions Definitions" dated 06/10/2017 published by the Department. This document is available at www.basix.nsw.gov.au

This certificate is a revision of certificate number A336749 02 lodged with the consent authority or certifier on 29 Nov 2019 with application DA2019/0080.

It is the responsibility of the applicant to verify with the consent authority that the original, or any revised certificate, complies with the requirements of Sch 1 Cl 2A, 4A or 6A of the Environmental Planning and Assessment Regulation 2000

Secretary Date of issue: Tuesday, 04, August 2020 To be valid, this certificate must be lodged within 3 months of the date of issue.



Planning, Industry & Environment

| Project name | 551B - 34 Beatty St, Balgowlah Heigh_05 |
|-----------------------|---|
| Street address | 34 Beatty Street Balgowlah Heights 2093 |
| Local Government Area | Northern Beaches Council |
| Plan type and number | Deposited Plan 350345 |
| Lot number | 21A |
| Section number | |
| Draigat turna | |
| Project type | |
| Dwelling type | Separate dwelling house |

Certificate Prepared by (please complete before submitting to Council or PCA)

Name / Company Name: ECOMODE Design

ABN (if applicable): 79845824261

| Pool and Spa | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|--|---------------------|---------------------------------------|--------------------|
| Rainwater tank | | | |
| The applicant must install a rainwater tank of at least 912 litres on the site. This rainwater tank must meet, and be installed in accordance with, the requirements of all applicable regulatory authorities. | ~ | ~ | ~ |
| The applicant must configure the rainwater tank to collect rainwater runoff from at least 40 square metres of roof area. | | \checkmark | \checkmark |
| The applicant must connect the rainwater tank to a tap located within 10 metres of the edge of the pool. | | \checkmark | \checkmark |
| Outdoor swimming pool | | 1 | |
| The swimming pool must be outdoors. | \checkmark | \checkmark | \checkmark |
| The swimming pool must not have a capacity greater than 35 kilolitres. | \checkmark | \checkmark | \checkmark |
| The swimming pool must have a pool cover. | | \checkmark | \checkmark |
| The swimming pool must be shaded. | \checkmark | \checkmark | |
| The applicant must install a pool pump timer for the swimming pool. | | \checkmark | \checkmark |
| The applicant must install the following heating system for the swimming pool that is part of this development: gas. | | \checkmark | \checkmark |

| Fixtures and systems | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|--|---------------------|---------------------------------------|--------------------|
| Hot water | | | |
| The applicant must install the following hot water system in the development: solar (gas-boosted) system that is eligible to create Renewable Energy Certificates under the (Commonwealth) Renewable Energy (Electricity) Regulations 2001 (incorporating Amendment Regulations 2005 (No. 2)). | ~ | ~ | ~ |
| Lighting | | | |
| The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light-emitting-diode (LED) lamps. | | ~ | ~ |
| Fixtures | | | |
| The applicant must ensure new or altered showerheads have a flow rate no greater than 9 litres per minute or a 3 star water rating. | | \checkmark | \checkmark |
| The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating. | | \checkmark | \checkmark |
| The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating. | | \checkmark | |

| Construction | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|---|---|---|-----------------------|---------------------------------------|--------------------|
| Insulation requirements | | | | | ł |
| | ation is not required where the area of new con | fs) in accordance with the specifications listed in struction is less than 2m2, b) insulation specified | ✓ | ~ | ~ |
| Construction | Additional insulation required (R-value) | Other specifications | | | |
| concrete slab on ground floor. | nil | | | | |
| external wall: brick veneer | R1.16 (or R1.70 including construction) | | | | |
| external wall: framed (weatherboard, fibro, metal clad) | R1.30 (or R1.70 including construction) | | | | |
| flat ceiling, pitched roof | ceiling: R2.50 (up), roof: foil/sarking | medium (solar absorptance 0.475 - 0.70) | | | |

| Glazing requ | irements | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|---|--------------|---|--------------------------|---------------------------|---|--|----------------------|---------------------------------------|--------------------|
| Windows and | l glazed do | ors | | | | | | | |
| The applicant n Relevant overs | ~ | | ~ | | | | | | |
| The following re | equirements | must also | be satisfie | ed in relation | to each window and glazed door: | | | \checkmark | \checkmark |
| Each window or glazed door with improved frames, or pyrolytic low-e glass, or clear/air gap/clear glazing, or toned/air gap/clear glazing must have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below. Total system U-values and SHGCs must be calculated in accordance with National Fenestration Rating Council (NFRC) conditions. The description is provided for information only. Alternative systems with complying U-value and SHGC may be substituted. | | | | | | | | ~ | ~ |
| | | | | | each eave, pergola, verandah, bal han 2400 mm above the sill. | cony or awning must be no more than 500 mm | | \checkmark | \checkmark |
| Pergolas with p | olycarbonate | e roof or si | milar tran | slucent mate | rial must have a shading coefficien | t of less than 0.35. | | \checkmark | \checkmark |
| External louvre | s and blinds | must fully | shade the | e window or g | glazed door beside which they are s | situated when fully drawn or closed. | | \checkmark | \checkmark |
| | | | | | e window or glazed door above which ons must not be more than 50 mm. | ch they are situated, unless the pergola also | | \checkmark | \checkmark |
| Overshadowing specified in the | | | | | t and distance from the centre and | the base of the window and glazed door, as | \checkmark | \checkmark | \checkmark |
| Windows an | d glazed o | doors g | lazing r | equiremer | nts | | _ | | |
| Window / door no. | Orientation | Area of glass inc. frame (m2) | Oversha Height (m) | dowing Distance (m) | Shading device | Frame and glass type | | | |
| WIN-108 | E | 1.25 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46) | | | |
| WIN-118 | W | 1.84 | 0 | 0 | eave/verandah/pergola/balcony >=750 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-120 | W | 2.7 | 15 | 13 | external louvre/blind (fixed) | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |

| Glazing requirements | | | | | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check |
|----------------------|-------------|--------------------------------|---------------|-----------------|---|--|---------------------|---------------------------------------|--------------------|
| Window / door | Orientation | | Oversha | dowing | Shading device | Frame and glass type | | | |
| no. | | glass inc. frame (m2) | Height (m) | Distance (m) | | | | | |
| WIN-119 | N | 16.3 | 0 | 0 | external louvre/blind (fixed) | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-124 | W | 13.97 | 12 | 13 | external louvre/blind (fixed) | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-406 | Ν | 17.85 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46) | | | |
| DR-401 | W | 12.8 | 8.3 | 6.8 | none | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46) | | | |
| DR-405 | E | 2 | 0 | 0 | eave/verandah/pergola/balcony >=600 mm | improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46) | | | |
| DR-410 | E | 3.57 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-412 | E | 8.32 | 3 | 7.6 | eave/verandah/pergola/balcony >=750 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-411 | E | 8.32 | 3 | 7.6 | eave/verandah/pergola/balcony >=750 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-413 | E | 19 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-121 | W | 4.3 | 0 | 0 | external louvre/blind (fixed) | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-120 | W | 2.8 | 0 | 0 | external louvre/blind (fixed) | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-407 | N | 3.33 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-125 | N | 9.9 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |

| Glazing requirements | | | | | | | | Show on CC/CDC Plans & specs | Certifier Check |
|----------------------|------------------|--------------------------------|---------------|-----------------|---|---|--------------|---------------------------------------|--------------------|
| Window / door | Orientation | Area of | Oversha | adowing | Shading device | Frame and glass type | | | |
| no. | | glass inc. frame (m2) | Height (m) | Distance (m) | | | | | |
| WIN-126 | N | 8.1 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-123 | N | 3.76 | 0 | 0 | external louvre/blind (fixed) | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-414 | W | 2.8 | 15 | 13 | external louvre/blind (fixed) | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-103 | E | 1.46 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-104 | E | 1.46 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-114 | E | 3.54 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| WIN-115 | S | 2.12 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-402 | E | 3.6 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-403 | E | 3.6 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-404 | E | 3.6 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| DR-409 | E | 4 | 0 | 0 | eave/verandah/pergola/balcony >=900 mm | improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75) | | | |
| Skylights | | | | | | | | 1 | |
| The applicant n | nust install the | e skylight | s in accor | dance with t | ne specifications listed in the table b | pelow. | \checkmark | | \checkmark |

| Glazing require | ements | | | Show on DA Plans | Show on CC/CDC Plans & specs | Certifier Check | |
|------------------------------------|--|--------------------------------|--|---------------------|---------------------------------------|--------------------|--|
| The following requ | The following requirements must also be satisfied in relation to each skylight: | | | | | | |
| Each skylight may the table below. | | \checkmark | \checkmark | | | | |
| External awnings | External awnings and louvres must fully shade the skylight above which they are situated when fully drawn or closed. | | | | | | |
| Skylights glaz | ing requiremer | nts | | - | | | |
| Skylight number | Area of glazing inc. frame (m2) | Shading device | Frame and glass type | | | | |
| WIN-301 | 0.45 | no shading | aluminium, moulded plastic single clear, (or U-value: 6.21, SHGC: 0.808) | | | | |
| WIN-302 | 0.85 | external fixed awning or blind | aluminium, moulded plastic single clear, (or U-value: 6.21, SHGC: 0.808) | | | | |

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a " / " in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a "
"
"
in the "Show on CC/CDC plans & specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.

Commitments identified with a " " in the "Certifier check" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate for the development may be issued.