

# Natural Environment Referral Response - Flood

Application Number:	DA2021/2119
•	
Date:	27/11/2021
То:	Claire Ryan
Land to be developed (Address):	Lot 1 DP 800640 , 154 Avalon Parade AVALON BEACH NSW 2107

#### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

#### Officer comments

The proposed DA involves a new boundary fence that generally complies with the flood controls in the LEP and DCP. The fence is proposed to have openings to allow stormwater to flow through (0.4m long X 0.2m high at 0.5m spacings).

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

#### **Recommended Natural Environment Conditions:**

# CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

# **Flooding**

In order to protect property and occupants from flood risk the following is required:

## Flood Effects Caused by Development – A2

There is to be no filling of the land or any other reduction of the available flood storage which results in a net loss of storage below the 1% AEP flood level.

# Building Components and Structural Soundness - B1

All new development below the Flood Planning Level of shall be designed and constructed as flood compatible buildings in accordance with Reducing Vulnerability of Buildings to Flood Damage: Guidance on Building in Flood Prone Areas, Hawkesbury-Nepean Floodplain Management Steering Committee (2006).

DA2021/2119 Page 1 of 2



# Building Components and Structural Soundness - B2

All new development must be designed to ensure structural integrity up to the Flood Planning Level.

#### Fencing – F1

New fencing (including pool fencing, boundary fencing, balcony balustrades and accessway balustrades) shall be open to allow for the unimpeded movement of flood waters. Refer to the Flood Report for 154 Avalon Parade, Avalon prepared by Pittwater Data Services dated 20/10/21

# Storage of Goods – G1

Storage areas for hazardous or potentially polluting materials shall not be located below the Flood Planning Level unless adequately protected from floodwaters in accordance with industry standards.

#### Recommendations

The development must comply with the recommendations outlined in the Flood Report for 154 Avalon Parade, Avalon prepared by Pittwater Data Services dated 20/10/21.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.

DA2021/2119 Page 2 of 2