


**ANNEXURE 6**



# Jack Hodgson Consultants Pty Limited

CONSULTING CIVIL, GEOTECHNICAL AND STRUCTURAL ENGINEERS

ABN: 94 053 405 011

**JOB NO: VR 23967**

## FACSIMILE COVER SHEET

<b>Date</b>	9/1/06	
<b>To</b>	Stephen Lesiuk	<b>FAX No.</b> 9974 5502
<b>Company</b>	Lesiuk Architects Pty Ltd	
<b>From</b>	Garth Hodgson	
<b>No. of pages (incl. this sheet)</b>	1	

**SUBJECT:- 1112 – 1116 Barrenjoey Road, Palm Beach**

After a discussion with Pittwater Council's Paul Brisby on the 18<sup>th</sup> December, 2006 regarding the estuarine planning level (EPL) for the subject address. The EPL is to set at 2.2 AHD approximately 0.2 metres above the stormwater grate level of 1.99 AHD in front of the property. This means the ramp for the basement car parking must achieve a level of 2.2 AHD before descending to protect the car parking from the possible flooding.

If you have any further questions regarding this matter please do not hesitate to contact us.

**JACK HODGSON CONSULTANTS PTY. LIMITED.**

**J. D. Hodgson M.Eng.Sc.,  
F.I.E.Aust., CP ENG.  
Civil & Structural Engineer.  
Nper3, Struct. Civil. No. 149788.  
Director.**

~ This facsimile message is intended for the addressee named and may contain privileged and/or confidential information. If you are not the intended recipient, please delete it and notify the sender. ~

DIRECTOR: J.D. HODGSON, M. Eng. Sc., F.I. E. Aust., Nper3 Struc. Civil 149788  
67 Darley Street, Mona Vale NSW 2103  
PO Box 389 Mona Vale NSW 1660  
Telephone: 9979 6733 Facsimile: 9979 6926