

## Environmental Health Referral Response - commercial use

<b>Application Number:</b>	DA2023/1708
<b>Proposed Development:</b>	Demolition works and construction of a Recreation Facility (indoor) with signage
<b>Date:</b>	14/05/2024
<b>To:</b>	Gareth David
<b>Land to be developed (Address):</b>	Lot 2743 DP 752038 , 431 Pittwater Road NORTH MANLY NSW 2100

### Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, accupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

### Officer comments

#### General Comments

This application is seeking consent for demolition works and construction of a recreation facility. The proposed facility includes a cafe with a WC directly beside. It is unclear if the WC is to be located in the dining space of the cafe or close to food prep/storage. A condition will apply to ensure compliance with sanitary facilities for cafe patrons. Environmental Health recommends approval subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Environmental Health and Protection Conditions:

## CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

#### Mechanical ventilation Plans

Where Mechanical ventilation is required to be installed in the food premises ,prior to any Construction Certificate (CC) being issued, detailed plans must be submitted to and approved by the Principle certifier that demonstrate compliance with the following:

- Australian Standard (AS) 1668.2 “The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings”; and
- Any external exhaust discharge must be above the roofline and discharged in a manner that is not likely to cause an amenity impact.

These plans are to be prepared by a suitably qualified person.

Reason: To ensure that the installed mechanical ventilation complies with the requirements of the Australian Standard 1668.2 and to prevent amenity impacts.

## **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

### **Toilet Facilities**

The WC for the cafe must be separated from areas where open food is handled, displayed or stored by an intervening ventilated space fitted with self-closing doors; or provided with self-closing doors and mechanical exhaust system that operate when the sanitary compartment is in use and for at least 30 seconds after the cubicle is vacated.

Reason: Legislative requirement.

### **Registration of food Business**

The food business must be registered with the appropriate regulatory authority, prior to the Occupation Certificate being issued.

Reason: Food premises are required to be registered with the Appropriate Regulatory Authority.

### **Kitchen Design, construction and fit out of food premises certification**

Prior to the issuing of any occupation certificate, certification is to be provided to the Principal Certifier by a suitably qualified person demonstrating that that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674 Design, construction and fit out of food premises.

Reason: To ensure that the kitchen complies with Australian Standard design requirements.

### **Mechanical Ventilation certification**

Where Mechanical ventilation is required to be installed in the food premises it must comply with the following:

- Australian Standard (AS) 1668.2 “The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings”; and
- Any external exhaust discharge must be above the roofline and discharged in a manner that is not likely to cause an amenity impact.

Certification is to be provided to the Principal Certifier prepared by a suitably qualified person to demonstrate that the mechanical ventilation complies with the above requirements.

Reason: To ensure that the installed mechanical ventilation complies with the requirements of the Australian Standard 1668.2 and to prevent amenity impacts.