

Natural Environment Referral Response - Flood

Application Number:	DA2020/1330
Date:	03/12/2020
To:	Thomas Prosser
Land to be developed (Address):	Lot 25 DP 19380 , 24 Trevor Road NEWPORT NSW 2106

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposed DA generally complies with the flood controls in the LEP and DCP. A new dwelling is proposed with a ground floor at the flood planning level (9.22m AHD). The garage is also at the FPL. The ground floor is above the PMF level (9.13m AHD) and can provide shelter in place. An alfresco outdoor area is proposed at 9.17m AHD. The proposed dwelling must remain open to allow for the free passage of floodwaters below the dwelling.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Flooding

In order to protect property and occupants from flood risk the following is required:

Building Components and Structural Soundness – C1

All new development shall be designed and constructed as flood compatible buildings in accordance with Reducing Vulnerability of Buildings to Flood Damage: Guidance on Building in Flood Prone Areas, Hawkesbury-Nepean Floodplain Management Steering Committee (2006).

Building Components and Structural Soundness – C2

All new development must be designed and constructed to ensure structural integrity up to the Flood Planning Level (9.22m AHD), taking into account the forces of floodwater, wave action,

flowing water with debris, buoyancy and immersion. Structural certification shall be provided confirming the above.

Building Components and Structural Soundness – C3

All new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections must be waterproofed and/or located above the Flood Planning Level. All existing electrical equipment and power points located below the Flood Planning Level must have residual current devices installed cut electricity supply during flood events.

Storage of Goods – D1

Hazardous or potentially polluting materials shall not be stored below the Flood Planning Level unless adequately protected from floodwaters in accordance with industry standards.

Flood Emergency Response – E2

Appropriate access to the shelter in place refuge should be available from all areas of the new development.

Floor Levels – F1

New floor levels within the development shall be set at or above the Flood Planning Level of 9.22m AHD.

Floor Levels – F2

The underfloor area of the dwelling below the 1% AEP flood level is to be designed and constructed to allow clear passage of floodwaters. The underfloor perimeter of the dwelling is to have a minimum of 50% open area below the 1% level (8.72m AHD).

Fencing – H1

Fencing (including pool fencing, boundary fencing, balcony balustrades and accessway balustrades) shall be open for passage of flood waters - All new fencing on the property must be design with a minimum of 50% open area between the 1% flood level and natural ground level, to allow flood waters to pass through.

Recommendations

The development must comply with all recommendations outlined in:

- The Flood Management Report prepared by Northern Beaches Consulting Engineers dated 2.10.2020.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.