

Water Management Referral Response

Application Number:	DA2022/0581
Date:	26/05/2022
To:	Adam Susko
Land to be developed (Address):	Lot 2 DP 1275526 , 1 Golf Avenue MONA VALE NSW 2103 Lot 249 DP 752046 (SPL 76319) Lot 323 DP 824000 (Crown Lease 200108) , 3 Golf Avenue MONA VALE NSW 2103 Lot 249 DP 752046 (SPL 76319) Lot 323 DP 824000 (Crown Lease 200108) , 3 Golf Avenue MONA VALE NSW 2103

Reasons for referral

Council's Water Management Officers are required to consider the likely impacts.

Officer comments

This application has been assessed against relevant legislation and policy relating to water quality, waterways, riparian areas, and groundwater.

NECC Water Management has no objections to the proposal.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Water Management Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan as required prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: Protection of the receiving environment.