



Building Code & Bushfire Hazard Solutions

(Pty. Limited) ABN 19 057 337 774
PO Box 124, Berowra NSW 2081
Telephone: (02) 9457 6530
www.bushfirehazardsolutions.com.au



Eaton Molina Architects
8-8 / 12 Pacific Parade,
DEE WHY NSW 2099

10th February 2023
Our Ref. 230316B

**RE: APPROVED DEMOLITION WORKS AND CONSTRUCTION OF A DWELLING HOUSE
INCLUDING SWIMMING POOLS
LOT 28 DP 8075, 32 BOWER STREET, MANLY NSW 2095
PROVISION OF UPDATED BUSHFIRE ASSESSMENT REPORT**

Dear Jake,

We understand that you are compiling the submission documents for a section 4.55 application seeking modifications to the approved alterations and additions at 32 Bower Street, Manly under development consent DA2019/0916, dated 26 February 2020.

The proposed modifications are shown in the plans by Eaton Molina Architects, project 0059, amendment D, dated 01.09.2022.

Building Code & Bushfire Hazard Solutions P/L (BCBHS) prepared a Bushfire Assessment Report (ref: 160013, dated 12th August 2015) addressing the relevant specifications and requirements of Planning for Bush Fire Protection 2006 for the original development application.

It is acknowledged that since the time the original development application was lodged Planning for Bush Fire Protection 2019 has come into effect and is applicable to all applications lodged on or after 1st March 2020.

We have reviewed the proposed modifications shown in the plans by Eaton Molina Architects, project 0059, amendment D, dated 01.09.2022. and the recommendations should be updated to the following:

Asset Protection Zones

1. That all grounds within the subject property not built upon are to be maintained as an Asset Protection Zone (Inner Protection Area) as detailed in the NSW Rural Fire Service's document 'Standards for Asset Protection Zones' and Appendix 4 of *Planning for Bush Fire Protection* 2019.

Landscaping

2. That any new landscaping is to comply with Section 3.7 'Landscaping' under *Planning for Bush Fire Protection* 2019.

Emergency management

3. That the occupants of the subject dwelling complete a Bush Fire Survival Plan.

With the above updated recommendations, we are therefore in support of the proposed section 4.55 modifications.

Should you have any questions please do not hesitate in contacting our office.

Prepared by
Building Code & Bushfire Hazard Solutions



Rob Crump
Trainee Bushfire Consultant

Reviewed and endorsed by
Building Code & Bushfire Hazard Solutions



Andrew Muirhead
Bushfire Consultant
Graduate Certificate in Bushfire Protection
Diploma of Engineering.
FPA Australia BPAD Level 2 Accredited Practitioner
BPAD Accreditation No. BPAD46966

