

Landscape Referral Response

Application Number:	DA2021/0317
Date:	16/04/2021
Responsible Officer:	Gareth David
Land to be developed (Address):	Lot 2 DP 833902 , 141 Riverview Road AVALON BEACH NSW 2107

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The development application is for the construction of a new dwelling on a vacant lot, including tree removal.

Council's Landscape Referral is assessed against the Pittwater Local Environment Plan clause E4 Environmental Living zone, and the following Pittwater 21 DCP Controls:

- B4.22 Preservation of Trees and Bushland Vegetation
- C1.1 Landscaping
- D1 Avalon Beach Locality

The site is located in the E4 Environmental Living zone, requiring development to achieve a scale integrated with the landform and landscape, and to minimise impact on the natural environment, including the retention of natural landscape features and existing trees.

No Landscape Plan is provided with the development application as required by Northern Beaches Council's DA Lodgement Requirements. A Arboricultural Impact Assessment is provided with recommendations for tree removal based on the proposed development footprint. A previous application for a car parking platform under development consent DA2019/1449 included tree removal approval with the current development application for a new dwelling and carport now requesting additional tree removal.

The area for residential building is limited to the proposed footprint that supports various native vegetation. Existing right of ways for vehicle access are used to access adjoining properties over the subject land that restricts development to the area where existing trees exist. Should this development proposal be approved, multiple existing Pittwater Spotted Gum Forest native trees located within the development footprint are impacted without design alternatives for retention including: six Spotted Gums, eight Black She Oak, three Sweet Pittosporums, 1 Ironbark and 1 Cabbage Tree Palm.

Tree replacement planting is required in order to satisfy the intent of the E4 zone and the landscape controls of C1.1 and conditions of consent shall be imposed.

Should this application be approved, conditions of consent are included by Landscape Referral.

The development application includes proposed encroachment by walling, stairs and ramps onto road reserve land and this is not approved as part of this application and shall be subject to formal approval or otherwise of a proposed encroachment under a Minor Encroachments/Constructions within Road Reserve 20/21 application.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Project Arborist

A Project Arborist with minimum AQF Level 5 in arboriculture shall be engaged to provide tree protection measures in accordance with Australian Standard 4970-2009 Protection of Trees on Development Sites. The Project Arborist is to specify and oversee all tree protection measures such as tree protection fencing, trunk and branch protection, and ground protection.

The Project Arborist is to supervise all demolition, excavation and construction works near all trees to be retained, including construction methods near the existing trees to protect tree roots, trunks, branches and canopy. Where required, manual excavation is to occur ensuring no tree root at or >25mm (Ø) is damaged by works, unless approved by the Project Arborist.

Existing ground levels shall be maintained within the tree protection zone of trees to be retained, unless authorised by the Project Arborist.

The Project Arborist shall be in attendance and supervise all works, including:

- i) excavation and construction works within the tree protection area of existing street trees (T11, T12, T20 and T21) within the road verge,
- ii) excavation and construction works within the tree protection area of existing trees (T28) within the site,
- iii) excavation and construction works within the tree protection area of existing trees (T4, T6, T22, T23, T24, T32, T34 and T36) located in adjoining properties.

All tree protection measures specified must:

- a) be in place before work commences on the site, and
- b) be maintained in good condition during the construction period, and
- c) remain in place for the duration of the construction works.

The Project Arborist shall provide certification to the Certifying Authority that all recommendations listed for the protection of the existing tree(s) have been carried out satisfactorily to ensure no impact to the health of the tree(s). Photographic documentation of the condition of all trees to be retained shall be recorded, including at commencement, during the works and at completion.

Note:

- i) A separate permit or development consent may be required if the branches or roots of a protected tree on the site or on an adjoining site are required to be pruned or removed.
- ii) Any potential impact to trees as assessed by the Project Arborist will require redesign of any

approved component to ensure existing trees upon the subject site and adjoining properties are preserved and shall be the subject of a modification application where applicable.

Reason: Tree protection.

Tree Removal within the Property

This consent approves the removal of the following tree(s) within the property (as recommended in the Arboricultural Impact Assessment):

i) T1, T2, T3, T5, T7, T13, T14, T15, T16, T17, T18, T19, T25, T26, T27, T29, T30, T33, T35 and T37.

Note: Exempt Species (T8 and T31) as listed in the Development Control Plan or the Arboricultural Impact Assessment do not require Council consent for removal.

Reason: To enable authorised building works.

Tree Removal within the Road Reserve

This consent approves the removal of the following tree(s) within the road reserve (as recommended in the Arboricultural Impact Assessment): T9 and T10 - both Black She Oak.

Removal of the approved tree/s in the road reserve shall only be undertaken by a Council approved tree contractor. Details of currently approved tree contractors can be obtained from Northern Beaches Council's Trees Services Section prior to removal.

Reason: Public liability.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Tree and Vegetation Protection

a) Existing trees and vegetation shall be retained and protected, including:

- i) all trees and vegetation within the site not approved for removal, excluding exempt trees and vegetation under the relevant planning instruments of legislation,
- ii) all trees and vegetation located on adjoining properties,
- iii) all road reserve trees and vegetation.

b) Tree protection shall be undertaken as follows:

- i) tree protection shall be in accordance with Australian Standard 4970-2009 Protection of Trees on Development Sites, including the provision of temporary fencing to protect existing trees within 5 metres of development,
- ii) existing ground levels shall be maintained within the tree protection zone of trees to be retained, unless authorised by an Arborist with minimum AQF Level 5 in arboriculture,
- iii) removal of existing tree roots at or >25mm (Ø) diameter is not permitted without consultation with an Arborist with minimum AQF Level 5 in arboriculture,
- iv) no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,
- v) structures are to bridge tree roots at or >25mm (Ø) diameter unless directed by an Arborist with minimum AQF Level 5 in arboriculture on site,
- vi) excavation for stormwater lines and all other utility services is not permitted within the tree protection zone, without consultation with an Arborist with minimum AQF Level 5 in arboriculture including advice on root protection measures,
- vii) should either or all of v), vi) and vii) occur during site establishment and construction works, an Arborist with minimum AQF Level 5 in arboriculture shall provide recommendations for tree protection measures. Details including photographic evidence of works undertaken shall be submitted by the

Arborist to the Certifying Authority,

viii) any temporary access to, or location of scaffolding within the tree protection zone of a protected tree or any other tree to be retained during the construction works is to be undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of Australian Standard 4970-2009 Protection of Trees on Development Sites,

ix) the activities listed in section 4.2 of Australian Standard 4970-2009 Protection of Trees on Development Sites shall not occur within the tree protection zone of any tree on the lot or any tree on an adjoining site,

x) tree pruning from within the site to enable approved works shall not exceed 10% of any tree canopy, and shall be in accordance with Australian Standard 4373-2007 Pruning of Amenity Trees,

xi) the tree protection measures specified in this clause must: i) be in place before work commences on the site, and ii) be maintained in good condition during the construction period, and iii) remain in place for the duration of the construction works.

c) Tree protection shall specifically be undertaken in accordance with the recommendations in the Arboricultural Impact Assessment.

The Certifying Authority must ensure that:

d) The arboricultural works listed in c) are undertaken and certified by an Arborist as compliant to the recommendations of the Arboricultural Impact Assessment.

e) The activities listed in section 4.2 of Australian Standard 4970-2009 Protection of Trees on Development Sites, do not occur within the tree protection zone of any tree, and any temporary access to, or location of scaffolding within the tree protection zone of a protected tree, or any other tree to be retained on the site during the construction, is undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of that standard.

Note: All street trees within the road verge and trees within private property are protected under Northern Beaches Council development control plans, except where Council's written consent for removal has been obtained. The felling, lopping, topping, ringbarking, or removal of any tree(s) is prohibited.

Reason: Tree and vegetation protection.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Required Tree Planting

Three (3) locally native trees (Spotted Gum - *Corymbia maculata*) shall be planted within the site in accordance with the following:

- i) tree planting at a minimum 75 litre container size shall be located within a 9m² deep soil area wholly within the site and be located a minimum of 3 metres from existing and proposed buildings and other trees,
- ii) tree planting shall be located to minimise significant impacts on neighbours in terms of blocking winter sunlight or where the proposed tree location may impact upon significant views,
- iii) tree planting shall be maintained until establishment including fertilising and watering, and thereafter for their safe useful life expectancy, and replaced should the trees fail due to lack of maintenance.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any Occupation Certificate.

Reason: To maintain environmental amenity.