

<b>Sent:</b>	6/04/2021 8:39:24 AM
<b>Subject:</b>	NSW RFS Determination - Your Reference - N0285/17 Mod2021/0071 (CNR-19521)
<b>Attachments:</b>	DA20210318001067-Original-1 - 01-04-2021 15_50_22 - Determination Letter.pdf;



## NSW RURAL FIRE SERVICE

**Attention:** Northern Beaches Council

**Your Reference:** N0285/17 Mod2021/0071 (CNR-19521)

**Application Details:** s4.14 – Infill – Original

**Site Address:**

81 Palmgrove Road  
Avalon Beach NSW 2107

Please find attached correspondence relating to the above development.

Should you wish to discuss this matter please contact Marc Ellwood on 1300 NSW RFS and quote DA20210318001067-Original-1.



**Planning and Environment Services**

**NSW RURAL FIRE SERVICE**

Locked Bag 17 Granville NSW 2142

**P** 1300 NSW RFS **E** [records@rfs.nsw.gov.au](mailto:records@rfs.nsw.gov.au)

[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au) | [www.facebook.com/nswrfs](https://www.facebook.com/nswrfs) | [www.twitter.com/nswrfs](https://www.twitter.com/nswrfs)

**PREPARE. ACT. SURVIVE.**



## NSW RURAL FIRE SERVICE

Northern Beaches Council  
PO Box 882  
MONA VALE NSW 1660

Your reference: N0285/17 Mod2021/0071 (CNR-19521)  
Our reference: DA20210318001067-Original-1

**ATTENTION:** Northern Beaches Council

Date: Tuesday 6 April 2021

Dear Sir/Madam,

**Development Application**  
**s4.14 - Infill - Secondary Dwelling**  
**81 Palmgrove Road Avalon Beach NSW 2107, 381//DP16902**

I refer to your correspondence dated 17/03/2021 seeking advice regarding bush fire protection for the above Development Application in accordance with section 4.14 of the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted and provides the following recommended conditions:

### Asset Protection Zones

***The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting fire fighting activities. To achieve this, the following conditions shall apply:***

1. From the start of building works, and in perpetuity to ensure ongoing protection from the impact of bush fires, the property around the building must be maintained as an inner protection area (IPA), in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*, as follows:

- south/south-east (towards the rear boundary of the property) for a distance of 33 metres; and,
- all other directions for a distance limited by the property boundaries.

When establishing and maintaining an IPA the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;

#### Postal address

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

#### Street address

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555  
F (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)

- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover; and
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.
- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed

### **Construction Standards**

***The intent of measures is that buildings are designed and constructed to withstand the potential impacts of bush fire attack. To achieve this, the following conditions shall apply:***

2. New construction to the east, west and south elevations of the secondary dwelling as well as to the roof of the secondary dwelling must comply with section 3 and section 6 (BAL 19) Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas – 2014* as appropriate and Section 7.5 of *Planning for Bush Fire Protection 2019*.

3. New construction to the north elevation of the secondary dwelling must comply with Sections 3 and 5 (BAL 12.5) Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas – 2014* as appropriate and Section 7.5 of *Planning for Bush Fire Protection 2019*.

### **Water and Utility Services**

***The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting fire fighting activities. To achieve this, the following conditions shall apply:***

4. The provision of water, electricity and gas must comply the following in accordance with Table 7.4a of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- all above-ground water service pipes external to the building are metal, including and up to any taps;
- where practicable, electrical transmission lines are underground;
- where overhead, electrical transmission lines are proposed as follows:
  - lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and
  - no part of a tree is closer to a power line than the distance set out in accordance with the specifications in ISSC3 Guideline for Managing Vegetation Near Power Lines.
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used;
- all fixed gas cylinders are kept clear of all flammable materials to a distance of 10m and shielded on the hazard side;
- connections to and from gas cylinders are metal;
- polymer-sheathed flexible gas supply lines are not used; and
- above-ground gas service pipes are metal, including and up to any outlets.

For any queries regarding this correspondence, please contact Marc Ellwood on 1300 NSW RFS.

Yours sincerely,

Emma Jensen

**Team Leader, Dev. Assessment & Planning  
Planning and Environment Services**