

## Building Assessment Referral Response

<b>Application Number:</b>	Mod2022/0630
<b>Date:</b>	01/12/2022
<b>To:</b>	Maxwell Duncan
<b>Land to be developed (Address):</b>	Lot 100 DP 1069144 , 75 The Corso MANLY NSW 2095 Lot 101 DP 1069144 , 75 The Corso MANLY NSW 2095 Lot 102 DP 1069144 , 75 The Corso MANLY NSW 2095 Lot 1 DP 1034722 , 42 North Steyne MANLY NSW 2095

### Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

### Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no concerns with the application subject to inclusion of the attached conditions of approval and consideration of the notes below.

*Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.*

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Building Assessment Conditions

#### **CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

#### **Condition for prior to construction certificate - Swimming Pool water**

##### **1. Swimming Pool water**

The backwash of Swimming Pool water must be discharged to Sydney Waters' sewer in accordance with Australian/New Zealand Standard AS/NZS 3500. Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate. The drawings must show the location of Sydney Water's sewer, the yard gully or any new connection to the sewer system including a detailed cross section of the connection complying with Australian/New Zealand Standard AS/NZS 3500.

**Reason:** To ensure compliance with legislation and Australian Standards and to protect public health and amenity.