

Environmental Health Referral Response - acid sulfate soils

Application Number:	DA2020/1142
---------------------	-------------

Date:	10/11/2020
Responsible Officer	Megan Surtees
,	Lot 194 DP 16719 , 15 Gondola Road NORTH NARRABEEN NSW 2101

Reasons for referral

This application seeks consent for one or more of the following:

- All development in class 1 land
- Any works below ground surface or will lower water table in area class 2 land
- Any works beyond 1 metre or lower water table by 1 metre in class 3 land
- Any works beyond 2 metres or lower water table by 2 metres in class 4 land
- Works on land below 10 metres AHD and within 500m of class 1, 2, 3 or 4 land which are likely to lower water table below 1 metre

And as such, Council's Environmental Investigations officers are required to consider the likely impacts.

Officer comments General Comments

Proposal to install a 1.7 m deep pool in Class 3 Acid Sulfate Soil is satisfactory. The applicant has tested for the presence of Acid Sulfate Soil. Results of the test demonstrated a neutral pH and no acidic soils - no condition recommended.

Recommendation

APPROVAL - without conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Investigations Conditions:

Nil.

DA2020/1142 Page 1 of 1