

Engineering Referral Response

Application Number:	DA2020/1759
Date:	10/06/2021
To:	Anne-Marie Young
Land to be developed (Address):	Lot 2 DP 233083 , 51 Arthur Street FORESTVILLE NSW 2087

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposal is not supported as the development requires the submission of a stormwater drainage plan detailing the provision of On site stormwater detention in accordance with Councils water management policy for development . A DRAINS hydraulic model is to be also prepared to support the sizing of a detention system.

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

Nil.