

## Environmental Health Referral Response - commercial use

<b>Application Number:</b>	DA2019/1496
<b>To:</b>	Nick England
<b>Land to be developed (Address):</b>	Lot 2 DP 1133931 , 18 Myoora Road TERREY HILLS NSW 2084

### Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, accupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

### Officer comments

#### General Comments

Environmental Health has reviewed this proposal considering food related matters. The proposal is approved subject to conditions.

### Recommendation

APPROVAL - subject to conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Environmental Health and Protection Conditions:

#### **CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

#### Registration of Food Business

The food business must be notified via the approved format with the Appropriate Regulatory Authority, prior to Occupation Certificate being issued.

Reason: Food premises are required to be registered with the Appropriate Regulatory Authority.

**Kitchen Design, construction and fit out of food premises certification**

Prior to the issuing of any interim / final occupation certificate, certification is to be provided from a suitably qualified person that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674:2004 Design, construction and fit out of food premises.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the kitchen complies with the design requirements.

**Mechanical Ventilation certification**

Prior to the issuing of any interim / final occupation certificate, certification is to be provided from the installer of the mechanical ventilation system that the design, construction and installation of the mechanical ventilation system is compliant with the requirements of AS1668 The use of mechanical ventilation.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To ensure that the mechanical ventilation system complies with the design requirements.