

FIRE SAFETY SCHEDULE

DA No: ⁻⁶⁸⁴⁰ 2011/1240

Shop Number/Name: ANYTIME FITNESS WARRINGAH - Shop X2-X4

Property Address: 145 Old Pittwater Road, BROOKVALE NSW 2100

Description of Development: Retail Tenancy Fitout

Essential fire safety measure	Standard of performance	
	Australian Standard	BCA Clause(s)
Access panels, doors & hoppers to fire resisting shafts	AS 1905.1 - 1997	C3.13
EXISTING <input checked="" type="checkbox"/>	PROPOSED <input type="checkbox"/>	
Automatic fail safe devices		C3.8, D2.21, Spec C3.4
EXISTING <input checked="" type="checkbox"/>	PROPOSED <input checked="" type="checkbox"/>	
Automatic fire detection & alarm systems (EWIS)	AS 1670 - 1995; AS 1603	Spec E2.2a
EXISTING <input checked="" type="checkbox"/>	PROPOSED <input checked="" type="checkbox"/>	
Automatic fire suppression systems (Sprinklers)	AS 2118.1 - 1999	Spec E1.5
EXISTING <input type="checkbox"/>	PROPOSED <input checked="" type="checkbox"/>	
Emergency lighting	AS/NZS 2293.1 - 1998	E4.4
EXISTING <input checked="" type="checkbox"/>	PROPOSED <input type="checkbox"/>	
Emergency warning and intercommunication systems	AS 2220.1 & 2 - 1989	E4.9, Spec G3.8
EXISTING <input type="checkbox"/>	PROPOSED <input checked="" type="checkbox"/>	
Exit signs	AS/NZS 2293.1 - 1998	E4.8
EXISTING <input checked="" type="checkbox"/>	PROPOSED <input type="checkbox"/>	
Fire dampers	AS 1668, AS 1682	
EXISTING <input checked="" type="checkbox"/>	PROPOSED <input checked="" type="checkbox"/>	
Fire doors	AS/NZS 1905.1 - 1997	Spec C3.4
EXISTING <input type="checkbox"/>	PROPOSED <input checked="" type="checkbox"/>	
Fire hydrant systems	AS 2419.1 - 1994	E1.3
EXISTING <input checked="" type="checkbox"/>	PROPOSED <input type="checkbox"/>	
Fire seals protecting openings in fire resisting components	AS 4072.1, AS 1530.4; AS 1038.15	Spec C3.15
EXISTING <input checked="" type="checkbox"/>	PROPOSED <input type="checkbox"/>	
Hose reel systems	AS 2441 - 1988	E1.4
EXISTING <input checked="" type="checkbox"/>	PROPOSED <input type="checkbox"/>	

Lightweight construction			C1.8, Spec C1.8
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		
Mechanical air handling systems (air conditioning)		AS 1668.1 & 2 - 1991	F4.5, F4.11, F4.12
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		
Portable fire extinguishers & fire blankets		AS 2444 - 1995	E1.6
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		
Smoke and heat vents		AS 2665 - 1983	Spec E2.2c, Spec G3.8 & NSW H101.22
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		
Smoke dampers		AS 1668.1 & 2	-
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		
Smoke detectors & heat detectors		AS 1670 - 1995	Spec E2.2a
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		
Smoke doors		-	Spec C3.4
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		
Solid core doors		-	C3.11, NSWC3.11(d)(ii)
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		
Warning and operational signs		-	C3.6, E3.3, D2.23 & Spec E1.8
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		
Required (Automatic) Exit Doors		AS 1670.1 - 1995	Clause D2.19
EXISTING	PROPOSED		
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		
Sliding Fire Doors		-	Clause C3.6
EXISTING	PROPOSED		
	<input type="checkbox"/>		
Smoke Control System		AS/NZS 1668.1 - 1998	Spec. E2.2a, E2.2b
EXISTING	PROPOSED		
	<input checked="" type="checkbox"/>		

Dated:

16/11/11

Signed:

S. W. J. A. S.