

Water Management Referral Response

Application Number:	Mod2021/0668
Date:	13/09/2021
To:	Alex Keller
Land to be developed (Address):	Lot CP SP 4129 , 48 A Queenscliff Road QUEENSCLIFF NSW 2096

Reasons for referral

Council's Water Management Officers are required to consider the likely impacts.

Officer comments

The project is proposing minor landscaping works.

The proposed modification to the approved DA are low environmental risk from a water quality management perspectives (stormwater and groundwater).

Sediment and erosion controls measures shall be maintained at all time during construction activity.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Water Management Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

Reason: Protection of the receiving environment.