

## Traffic Engineer Referral Response

Application Number:	DA2018/1993
---------------------	-------------

Responsible Officer	
Land to be developed (Address):	<p>Lot 9 DP 629464 , 104 Cabarita Road AVALON BEACH NSW 2107</p> <p>Lot 8 DP 629464 , 102 Cabarita Road AVALON BEACH NSW 2107</p> <p>Lot 15 DP 858130 , 100 Cabarita Road AVALON BEACH NSW 2107</p> <p>Lot 14 DP 858130 , 96 Cabarita Road AVALON BEACH NSW 2107</p>

### Officer comments

Proposal is for a single dwelling to be provided in the approved subdivided lots.

#### Traffic:

One Dwelling will produce 0.85 trips in the peak. This equates to 1 vehicle per hour. This is deemed negligible on the local traffic network.

#### Parking:

One dwelling requires 2 spaces in accordance with Council's DCP. The site has provided 2 spaces for this dwelling. This is deemed adequate.

#### Pedestrian:

Pedestrian access is deemed satisfactory.

#### Access:

Driveway widths are deemed satisfactory.

#### Servicing:

All servicing will occur from the street. No changes to waste arrangements.

### Referral Body Recommendation

### Refusal comments

### Recommended Traffic Engineer Conditions:

**CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

### Compliance with Standards

The development is required to be carried out in accordance with all relevant Australian Standards.

(Note: At the time of determination the following (but not limited to) Australian Standards applied:

- (a) AS2601.2001 - Demolition of Structures\*\*
- (b) AS4361.2 - Guide to lead paint management - Residential and commercial buildings\*\*
- (c) AS4282:1997 Control of the Obtrusive Effects of Outdoor Lighting\*\*
- (d) AS 4373 - 2007 'Pruning of amenity trees' (Note: if approval is granted) \*\*
- (e) AS 4970 - 2009 'Protection of trees on development sites'\*\*\*
- (f) AS/NZS 2890.1:2004 Parking facilities - Off-street car parking\*\*
- (g) AS 2890.2 - 2002 Parking facilities - Off-street commercial vehicle facilities\*\*
- (h) AS 2890.3 - 1993 Parking facilities - Bicycle parking facilities\*\*
- (i) AS 2890.5 - 1993 Parking facilities - On-street parking\*\*
- (j) AS/NZS 2890.6 - 2009 Parking facilities - Off-street parking for people with disabilities\*\*
- (k) AS 1742 Set - 2010 Manual of uniform traffic control devices Set\*\*
- (l) AS 1428.1 – 2009\* Design for access and mobility - General requirements for access – New building work\*\*
- (m) AS 1428.2 – 1992\*, Design for access and mobility - Enhanced and additional requirements - Buildings and facilities\*\*

\*Note: The Australian Human Rights Commission provides useful information and a guide relating to building accessibility entitled "the good the bad and the ugly: Design and construction for access". This information is available on the Australian Human Rights Commission website [www.hreoc.gov.au/disability rights /buildings/good.htm](http://www.hreoc.gov.au/disability%20rights/buildings/good.htm). <[www.hreoc.gov.au/disability%20rights%20/buildings/good.htm](http://www.hreoc.gov.au/disability%20rights%20/buildings/good.htm)>

\*\*Note: the listed Australian Standards is not exhaustive and it is the responsibility of the applicant and the Certifying Authority to ensure compliance with this condition and that the relevant Australian Standards are adhered to.)

Details demonstrating compliance with the relevant Australian Standard are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure the development is constructed in accordance with appropriate standards.  
(DACPLC02)

### **Construction Traffic Management Plan**

A CTMP is to be submitted to and approved by the Certifying Authority prior to the issue of any Construction Certificate. The CTMP must be in accordance with RMS Guidelines for preparation of a Construction Traffic Management Plan.

Reason: To ensure all construction vehicular activities are managed with minimal impact on the local road network (DACTRCPC1)