

## Natural Environment Referral Response - Flood

<b>Application Number:</b>	DA2020/1135
<b>Date:</b>	08/10/2020
<b>To:</b>	Anne-Marie Young
<b>Land to be developed (Address):</b>	Lot 8 DP 25959 , 14 Lalchere Street CURL CURL NSW 2096

### Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

The proposed development is for demolition of an existing dwelling and construction of a 2 level dwelling. Subject to conditions, the development is compliant with Council's Flood Prone Land development controls.

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Natural Environment Conditions:

#### Flooding

In order to protect property and occupants from flood risk the following is required:

##### Building Components and Structural Soundness – C1

All new development shall be designed and constructed as flood compatible buildings in accordance with Reducing Vulnerability of Buildings to Flood Damage: Guidance on Building in Flood Prone Areas, Hawkesbury-Nepean Floodplain Management Steering Committee (2006).

##### Building Components and Structural Soundness – C2

All new development must be designed and constructed to ensure structural integrity up to the Probable Maximum Flood level of 5.7m AHD, taking into account the forces of floodwater, wave action, flowing water with debris, buoyancy and immersion. Structural certification shall be provided confirming the above.

##### Building Components and Structural Soundness – C3

All new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections must be waterproofed and/or located above the Flood Planning Level of 4.16m AHD. All existing electrical equipment and power points located below the Flood Planning Level must have residual current devices installed cut electricity supply during flood events.

#### Flood Emergency Response – E2

Appropriate access to the shelter in place refuge ( first floor) should be available from all areas of the new development.

#### Floor Levels – F1

New habitable ground floor levels within the development shall be set at or above the Flood Planning Level of 4.16m AHD.

#### Floor Levels – F2

The underfloor area of the dwelling (excluding the garage) below the 1% AEP flood level is to be designed and constructed to allow clear passage of floodwaters. The underfloor perimeter of the dwelling is to have a minimum of 50% open area below the 1% level

#### Car parking – G5

The floor level of the proposed garage shall be set at or above the 1 in 100 year flood level of 3.66m AHD.

#### Fencing – H1

New fencing (including pool fencing, boundary fencing, balcony balustrades and accessway balustrades) shall be open for passage of flood waters - All new fencing on the property must be design with a minimum of 50% open area between the 1% flood level of 3.66m AHD and natural ground level, to allow flood waters to pass through.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Construction Certificate.

**Reason:** To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.