

Building Assessment Referral Response

Application Number:	DA2019/0444
To:	Rhiannon McLardy
Land to be developed (Address):	Lot 1 DP 14433 , 31 Carawa Road CROMER NSW 2099

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

Garage Top Dwelling – Fire Safety Measures

Where building works involve a Class 1a Secondary Dwelling above a non-appurtenant private garage, fire separation works are to be carried out in accordance with the provisions of 3.7.1 Volume Two of the Building Code of Australia.

Full details are to be provided with the Construction Certificate and works are to be completed / implemented prior to the issue of any interim or final Occupation Certificate.

Reason: To ensure adequate provision is made for fire safety in the premises and for building occupant safety.

Laundry Facilities (Class)

The layout of the bathroom/laundry area is to be designed/modified to incorporate clothes washing facilities, comprising of at least one washtub and space in the same room for a washing machine in accordance with Part 3.8.3 of the Building Code of Australia –‘Facilities’.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the

Construction Certificate.

Reason: To ensure adequate provision is made for building occupant health and amenity

Recommended Building Assessment Conditions

Nil.