

Waste Referral Response

Application Number:	DA2021/0053
Date:	19/03/2021
To:	Jordan Davies
Land to be developed (Address):	<p>Lot 7 DP 1251955 , 121 Dove Lane WARRIEWOOD NSW 2102</p> <p>Lot 1 DP 1266557 , 111 Dove Lane WARRIEWOOD NSW 2102</p> <p>Lot 4 DP 1251955 , 101 Dove Lane WARRIEWOOD NSW 2102</p>

Reasons for referral

This application seeks consent for the following:

- new residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- mixed use developments containing three or more residential dwellings. or
- new subdivisions of three or more lots. (Private road and public road subdivisions) or

And as such, Councils Waste Management Officers are required to consider the likely impacts on drainage regimes.

Officer comments

Waste Management Assessment

This proposal requires assessment of both the subdivision and the dwellings. Conditions of consent have been provided for both including one special condition for the subdivision. If more than one community association is created from this subdivision then the conditions of consent apply equally to both.

Recommendation - approved subject to conditions.

Ray Creer
Waste Services Officer

The proposal is therefore unsupported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Waste Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Waste and Recycling Requirements

Details demonstrating compliance with Northern Beaches Waste Management Guidelines, are to be submitted to and approved by the Certifying Authority prior to the issue of any Construction Certificate.

Note: If the proposal, when compliant with the Northern Beaches Waste Management Guidelines, causes inconsistencies with other parts of the approval i.e. architectural or landscaped plans, a modification(s) to the development may be required.

Reason: To ensure adequate and appropriate waste and recycling facilities are provided.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**Waste/Recycling Requirements (Waste Plan Submitted)**

During demolition and/or construction the proposal/works shall be generally consistent with the submitted Waste Management Plan titled dated [INSERT].

Reason: To ensure waste is minimised and adequate and appropriate waste and recycling facilities are provided.

Waste/Recycling Requirements (Materials)

During demolition and/or construction the following materials are to be separated for recycling: timber, bricks, tiles, plasterboard, metal, concrete, and evidence of disposal for recycling is to be retained on site.

Reason: To ensure waste is minimised and recovered for recycling where possible.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE****Garbage and Recycling Facilities**

All internal walls of the waste rooms shall be rendered to a smooth surface, coved at the floor/wall intersection, graded and appropriately drained to the sewer with a tap in close proximity to facilitate cleaning.

Waste room floors shall be graded and drained to an approved Sydney Water drainage system.

Waste rooms shall be clear of any other services or utilities infrastructure such as gas, electricity air-conditioning, plumbing, piping ducting or equipment.

Reason: To prevent pollution of the environment, provide a safe workplace for contractors and residents and to protect the amenity of the area.

Waste and Recycling Facilities Certificate of Compliance

The proposal shall be constructed in accordance with the Northern Beaches Waste Management Guidelines.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure waste and recycling facilities are provided.

Waste/Recycling Compliance Documentation

Evidence of disposal for recycling from the construction/demolition works shall be submitted to the Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure waste is minimised and recycled.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Positive Covenant for Council and Contractor Indemnity

A positive covenant shall be created on the title of the land prior to the issue of a Subdivision Certificate requiring the proprietor of the land to provide access to the waste storage facilities. The terms of the positive covenant are to be prepared to Council's requirements, (Appendix E of the Waste Management Guidelines), at the applicant's expense and endorsed by Council prior to lodgement with NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant.

Reason: To ensure ongoing access for servicing of waste facilities.

Access for Waste Collection Vehicles

The privately owned right of carriageways must remain free of parked cars and other obstructions from 6.00am to 6.00pm on the scheduled day of waste collection.

Reason: To ensure unimpeded access for waste collection vehicles.

CONDITIONS THAT MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF ANY STRATA SUBDIVISION OR SUBDIVISION CERTIFICATE

Authorisation of Legal Documentation Required for Waste Services

The original completed request form (NSW Land Registry Services standard form 13PC) must be submitted to Council for authorisation prior to the issue of the Subdivision Certificate. A copy of the work-as-executed plan (details overdrawn on a copy of the approved plan) must be included with the above submission. Where required by Council or the Certifying Authority, a Compliance Certificate shall also be provided in the submission to Council.

If Council is to issue the Compliance Certificate for these works, the fee is to be in accordance with Council's Fees and Charges.

Reason: To create encumbrances on the land.

Neighbourhood Management Statement for Waste Services

Where a development proposes the creation of a neighbourhood scheme, the Neighbourhood Management Statement shall include wording in relation to the provision of waste services in accordance with Appendix D of Northern Beaches Council Waste Management Guidelines

Reason: To ensure ongoing access for servicing of waste facilities.

Load Bearing Capacity of Stormwater Infrastructure.

Structural engineering certification be provided to Council demonstrating that all stormwater infrastructure paved underneath the road pavement (of both public and privately owned roads) can withstand a minimum load of 23 tonnes (waste collection vehicle).

Reason: To ensure stormwater infrastructure is constructed to carry the weight of waste collection vehicles.