

## Natural Environment Referral Response - Coastal

Application Number:	DA2021/1163
Date:	21/07/2021
Responsible Officer	Kent Bull
Land to be developed (Address):	Lot 6 DP 6555 , 120 Garden Street NORTH NARRABEEN NSW 2101

### Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

### Officer comments

This application was assessed in consideration of:

Supplied plans and reports

Coastal Management Act

Coastal Management SEPP (Clauses, 13, 14 and 15)

Relevant LEP and DCP clauses

The application meets the requirements of the relevant Environmental Planning Instruments and policies.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Natural Environment Conditions:

#### CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

##### Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site