

Engineering Referral Response

Application Number:	DA2019/0847
To:	Catriona Shirley
Land to be developed (Address):	Lot 12 DP 10167 , 5 Florida Road PALM BEACH NSW 2108

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m² or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

Onsite Detention Tank:

The proposed Stormwater Concept Plan is unsatisfactory. The scale of development requires provision for OSD in accordance Pittwater DCP clause B5.7.

Access:

Insufficient information has been provided with regard to the proposed access driveway. The Applicant shall provide a traffic report to demonstrate that *site distance at proposed access driveway complies* with Pittwater DCP21 Section B6 and AS/NZS 2890.1:2004 Section 3.

The proposed application cannot be supported by Development Engineering due to insufficient information to address:

- Parking facilities for the development in accordance with clause B6 Access and Parking
- Stormwater drainage for the development in accordance with clause B5 Stormwater

Additional Information Received 27/09/2019

The submitted Stormwater Concept Plan and Vehicle Line Analysis address the relevant DCP controls. No objections are raised to the proposed development, subject to conditions.

Referral Body Recommendation

Recommended for approval, subject to conditions

Refusal comments

Recommended Engineering Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Geotechnical Report Recommendations have been Incorporated into Designs and Structural Plans

The recommendations of the risk assessment required to manage the hazards as identified in the Geotechnical Report prepared by White geotechnical group dated 26th June 2019 are to be incorporated into the construction plans. Prior to issue of the Construction Certificate, Form 2 of the Geotechnical Risk Management Policy for Pittwater (Appendix 5 of P21 DCP) is to be completed and submitted to the Accredited Certifier. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure geotechnical risk is mitigated appropriately.

Submission Roads Act Application for Civil Works in the Public Road

An Application for Works to be approved within Council Roadway, including engineering plans is to be submitted to Council for approval under the provisions of Sections 138 and 139 of the Roads Act 1993. The application is to include four (4) copies of Civil Engineering plans for the design of driveway, stairs and retaining walls which are to be generally in accordance with the Development Application and Council's specification for engineering works - AUS-SPEC #1 and Council's Minor Works Policy. The plan shall be prepared by a qualified structural engineer. The design must include the following information: The fee associated with the assessment and approval of the application is to be in accordance with Council's Fee and Charges. An approval is to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate

Reason: To provide public and private safety.

On-site Stormwater Detention

An On-site Stormwater Detention system must be designed and constructed in accordance with Northern Beaches Council's current PITTWATER DCP21 and generally in accordance with the concept drainage plans prepared by NB Consulting Engineers, Job Number 190525, drawing number D01, D02 & D03 and dated 23 September 2019.

Detailed drainage plans, including engineering certification confirming the above requirements have been satisfied and complying with Council's requirements, are to be submitted to the Principal Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for the disposal of storm water and storm water management arising from the development.

Structural Adequacy and Excavation Work

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required. All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

(a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and

(b) Comply with AS3700, AS3600 and AS1170 and timber walls with AS1720 and AS1170.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To provide public and private safety.

Shoring of Adjoining Property

Should the proposal require shoring to support an adjoining property or Council land, owner's consent for the encroachment onto the affected property owner shall be provided with the engineering drawings.

Council approval is required if temporary ground anchors are to be used within Council land. A Temporary Ground Anchors (Road Reserve) Application is to be submitted with Council for assessment and approval subject to Council's Fees and Charges. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate

Reason: To ensure that owners consent is obtained for ancillary works, and to ensure the protection of adjoining properties and Council land.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Road Reserve

The public footways and roadways adjacent to the site shall be maintained in a safe condition at all times during the course of the work.

Reason: Public Safety.

Vehicle Crossings

The provision of one vehicle crossing 5.0 metres wide in accordance with Northern Beaches Council Drawing No A4-3330/4 EH and specifications. An Authorised Vehicle Crossing Contractor shall construct the vehicle crossing and associated works within the road reserve in plain concrete. The driveway and retaining walls must be designed in accordance with Australian Standards AS2890.1 and Northern Beaches Council Pittwater DCP B6 vehicular sight-line specifications. All redundant laybacks and crossings are to be restored to footpath/grass. Prior to the pouring of concrete, the vehicle crossing is to be inspected by Council and a satisfactory "Vehicle Crossing Inspection" card issued.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority.

Reason: To facilitate suitable vehicular access to private property.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Stormwater Disposal

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person. Details demonstrating compliance are to be submitted to the

Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development.

Positive Covenant and Restriction as to User for On-site Stormwater Detention

The Applicant shall lodge the Legal Documents Authorisation Application with the original completed request forms (NSW Land Registry standard forms 13PC and/or 13RPA) to Council including a copy of the Works-as-Executed plan (details overdrawn on a copy of the approved drainage plan) and a hydraulic engineers' certification.

The Applicant shall create on the Title a restriction on the use of land and a positive covenant in respect to the ongoing maintenance and restriction of the on-site stormwater detention/disposal structures within this development consent. The terms of the positive covenant and restriction are to be prepared to Council's standard requirements at the applicant's expense and endorsed by Northern Beaches Council's delegate prior to lodgement with the NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant.

A copy of the certificate of title demonstrating the creation of the positive covenant and restriction as to user for on-site storm water detention/disposal is to be submitted to the Certifying Authority prior to the issue of final Occupation Certificate.

Reason: To ensure the on-site stormwater detention/disposal system is maintained to an appropriate operational standard.

Geotechnical Certification Prior to Occupation Certificate

Prior to issue of the Occupation Certificate, Form 3 of the Geotechnical Risk Management Policy is to be completed and submitted to the Principal Certifying Authority.

Reason: To ensure geotechnical risk is mitigated appropriately.