

Building Assessment Referral Response

DA2020/0823
28/07/2020
Tony Collier
Lot 101 DP 868560, 93 McIntosh Road NARRAWEENA NSW 2099

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

NSW 2099

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

No objections subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Fire Safety Matters

At the completion of all works, a Fire Safety Certificate will need to be prepared which references all the Essential Fire Safety Measures applicable and the relative standards of Performance (as per Schedule of Fire Safety Measures). This certificate must be prominently displayed in the building and copies must be sent to Council and Fire and Rescue NSW.

Details demonstrating compliance are to be submitted to the Certifying Authority prior to the issue of the Occupation Certificate (or where applicable, relating to the part of the building, being the subject of this Consent).

DA2020/0823 Page 1 of 2



Each year the Owners must send to the Council and Fire and Rescue NSW, an annual Fire Safety Statement which confirms that all the Essential Fire Safety Measures continue to perform to the original design standard.

Reason: Statutory requirement under Part 9 Division 4 & 5 of the Environmental Planning and Assessment Regulation 2000.

CONDITIONS THAT MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF ANY STRATA SUBDIVISION OR SUBDIVISION CERTIFICATE

Compliance with Relevant Legislation

Prior to the issue of the Strata Plan of Subdivision, all relevant matters pertaining to this Plan, are to be satisfied to the satisfaction of the Certifying Authority, and evidence provided that the Plan complies with clause 17 Strata Schemes Development Regulation 2016 and the relevant parts of Section 54 or 58 Strata Schemes Development Act 2015.

Reason: To ensure compliance with the Consent issued, compliance with relevant legislation, and to ensure adequate provision is made, where required for fire safety, occupant safety, egress and appropriate facilities in the premises for building occupants.

DA2020/0823 Page 2 of 2