

Environmental Health Referral Response - commercial use

Application Number:	DA2022/1510
Date:	05/10/2022
To:	Adam Susko
Land to be developed (Address):	Part Lot 28 DP 7413 , 9 Francis Street DEE WHY NSW 2099 Part Lot 28 DP 7413 , 28 Fisher Road DEE WHY NSW 2099 Part Lot 28 DP 7413 , 28 Fisher Road DEE WHY NSW 2099

Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, acupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

Officer comments

General Comments

Proposed cafe as part of a larger multi use Development
Environmental Health supports the proposal subject to conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Health and Protection Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Plans of Kitchen Design, construction and fit out

Prior to any Construction Certificate (CC) being issued, detailed plans that demonstrate compliance with Standard 3.2.3 of the Australian and New Zealand Food Standards Code, the Food Act 2003 and Australian Standard AS 4674 'Design, construction and fit out of food premises', must be submitted to and approved by the Principle certifier. These plans are to be prepared by a suitably qualified person.

The plans must detail adequate provision for storage including separate storage of food, equipment, chemicals and personal belongings.

Reason: To ensure that the food premises complies with the design construction and fit-out requirements.

Mechanical ventilation Plans

Where Mechanical ventilation is required to be installed in the food premises ,prior to any Construction Certificate (CC) being issued, detailed plans must be submitted to and approved by the Principle certifier that demonstrate compliance with the following:

- Australian Standard (AS) 1668.2 “The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings”; and
- Any external exhaust discharge must be above the roofline and discharged in a manner that is not likely to cause an amenity impact.
- Provision of smoke and odour control equipment where necessary dependent on any cooking activity to prevent any nuisance to neighbouring residential premises and the roof deck common area

These plans are to be prepared by a suitably qualified person.

Reason: To ensure that the installed mechanical ventilation complies with the requirements of the Australian Standard 1668.2 and to prevent amenity impacts.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE****Registration of food Business**

The food business must be registered with the Appropriate Regulatory Authority, prior to Occupation Certificate being issued.

Reason: Food premises are required to be registered with the Appropriate Regulatory Authority.

Kitchen Design, construction and fit out of food premises certification

Prior to the issuing of any occupation certificate, certification is to be provided to the Principal Certifier by a suitably qualified person demonstrating that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674 Design, construction and fit out of food premises.

Reason: To ensure that the kitchen complies with Australian Standard design requirements.

Mechanical Ventilation certification

Where Mechanical ventilation is required to be installed in the food premises it must comply with the following:

- Australian Standard (AS) 1668.2 “The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings”; and
- Any external exhaust discharge must be above the roofline and discharged in a manner that is not likely to cause an amenity impact.
- Demonstrate that there is adequate provision of smoke and odour control equipment to prevent any nuisance to neighboring residential premises and the roof deck common area.

Certification is to be provided to the Principal Certifier prepared by a suitably qualified person to demonstrate that the mechanical ventilation complies with the above requirements.

Reason: To ensure that the installed mechanical ventilation complies with the requirements of the

Australian Standard 1668.2 and to prevent amenity impacts.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

Cafe Hours

Cafe hours being restricted 6am to 6pm Monday to Sunday as envisaged by the acoustic assessment by TTM Consulting Pty Ltd 8/8/2022

Reason: To minimise a potential noise nuisance to neighbouring receivers