

Natural Environment Referral Response - Riparian

Application Number:	DA2019/0309
То:	Phil Lane
Land to be developed (Address):	Lot 171 DP 15376 , 257 Whale Beach Road WHALE BEACH

Reasons for referral

This application seeks consent for the following:

 All Development Applications on land, and located within 40 metres of land, containing a watercourse, or

NSW 2107

- All Development Applications on land containing a wetland, or located within 100m of land containing a wetland,
- All Development Applications on land that is mapped as "DCP Map Waterways and Riparian Land".

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

This application is recommended for approval and satisfies Pittwater 21 DCP B5.8 and B5.11. Stormwater drainage must be installed as shown on the Stormwater Concept Plan Revision B provided by SGC Engineering.

Sediment and erosion controls must be installed prior to any work on site and maintained until work is complete and groundcover re-established.

Referral Body Recommendation

Recommended for approval, subject to conditions

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Stormwater drainage

Stormwater drainage must be installed as shown on the Stormwater Concept Plan Revision B provided by SGC Engineering.

Reason: Protection of the receiving environment (DACNECPCC1)

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban

DA2019/0309 Page 1 of 2



Stormwater: Soils and Construction' (2004).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site (DACNED06)

DA2019/0309 Page 2 of 2