

Engineering Referral Response

Application Number:	DA2025/0659
Proposed Development:	Alterations and additions to a dwelling house
Date:	17/06/2025
То:	
Land to be developed (Address):	Lot 31 DP 24555 , 7 Landscape Avenue FORESTVILLE NSW 2087

Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m2 or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

Officer comments

he Applicant is seeking approval to convert the existing carport into a double garage. The subject site is affected by Council's stormwater drainage system; however, the proposed works appear to be sufficiently clear of Council's drainage asset.

There are no objections from Development Engineering, subject to the imposition of appropriate conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Engineering Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Road Reserve

DA2025/0659 Page 1 of 2



The applicant shall ensure the public footways and roadways adjacent to the site are maintained in a safe condition at all times during the course of the work.

Reason: Public safety.

Property Boundary Levels

The Applicant is to maintain the property boundary levels. No approval is granted for any change to existing property alignment levels to accommodate the development.

Details demonstrating compliance are to be submitted to the Principal Certifier.

Reason: To maintain the existing profile of the nature strip/road reserve.

DA2025/0659 Page 2 of 2