

Natural Environment Referral Response - Coastal

Application Number:	DA2022/1430
Date:	27/09/2022
Responsible Officer	Grace Facer
Land to be developed (Address):	Lot 17 DP 5857 , 12 Austral Avenue NORTH MANLY NSW 2100

Reasons for referral

This application seeks consent for land located within the Coastal Zone.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

SUPPORTED WITH CONDITIONS

The application has been assessed in consideration of the *Coastal Management Act 2016*, State Environmental Planning Policy (Resilience & Hazards) 2021 and has also been assessed against requirements of the Warringah LEP 2011 and Warringah DCP 2011.

Coastal Management Act 2016

The subject site has been identified as being within the coastal zone and therefore *Coastal Management Act 2016* is applicable to the proposed development. The proposed development is in line with the objects, as set out under Clause 3 of the *Coastal Management Act 2016*.

State Environmental Planning Policy (Resilience & Hazards) 2021

The subject land has been included on the 'Coastal Environment Area' map under the State Environmental Planning Policy (Resilience & Hazards) 2021. Hence, Clauses 2.10 and 2.12 of the CM (R & H) apply for this DA.

Comment:

On internal assessment, the DA satisfies requirements under clauses 2.10 and 2.12 of the SEPP R&H. As such, it is considered that the application does/does not comply with the requirements of the State Environmental Planning Policy (Resilience & Hazards) 2021

Warringah LEP 2011 and Warringah DCP 2011

No other coastal related issues identified.

As such, it is considered that the application does comply with the requirements of the coastal relevant clauses of the Warringah LEP 2011 and Warringah DCP 2011.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Installation and Maintenance of Sediment and Erosion Control

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004). Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To protect the surrounding environment from the effects of sedimentation and erosion from the site