



NSW RURAL FIRE SERVICE

Northern Beaches Council
PO Box 882
MONA VALE NSW 1660

Your reference: DA2020/0187 (CNR-5485)
Our reference: DA20200303000846-Original-1

ATTENTION: Kylie Bridge

Date: Monday 6 April 2020

Dear Sir/Madam,

Development Application
s4.14 - Other - Single Dwelling - Alterations & Additions
48 Beacon Avenue Beacon Hill NSW 2100, 6//DP31216

I refer to your correspondence dated 03/03/2020 seeking advice regarding bush fire protection for the above Development Application in accordance with section 4.14 of the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted and provides the following recommended conditions:

Asset Protection Zones

The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting fire fighting activities. To achieve this, the following conditions shall apply:

[APZ 1.0]

From the start of building works, the entire property must be managed as an inner protection area (IPA). The IPA must comprise:

- Minimal fine fuel at ground level;
 - Grass mowed or grazed;
 - Trees and shrubs retained as clumps or islands and do not take up more than 20% of the area;
 - Trees and shrubs located far enough from buildings so that they will not ignite the building;
 - Garden beds with flammable shrubs not located under trees or within 10 metres of any windows or doors;
 - Minimal plant species that keep dead material or drop large quantities of ground fuel;
 - Tree canopy cover not more than 15%;
 - Tree canopies not located within 2 metres of the building;
 - Trees separated by 2-5 metres and do not provide a continuous canopy from the hazard to the building;
- and,

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

- Lower limbs of trees removed up to a height of 2 metres above the ground.

Construction Standards

The intent of measures is that buildings are designed and constructed to withstand the potential impacts of bush fire attack. To achieve this, the following conditions shall apply:

[D&C 1.2]

New construction must comply with section 3 and section 7 (BAL 29) Australian Standard AS3959-2009 'Construction of buildings in bush fire-prone areas' or NASH Standard (1.7.14 updated) 'National Standard Steel Framed Construction in Bushfire Areas – 2014' as appropriate and section A3.7 Addendum Appendix 3 of Planning for Bush Fire Protection 2006'.

Landscaping Assessment

The intent of measures is for landscaping. To achieve this, the following conditions shall apply:

[L 1.0]

Landscaping of the site should comply with following principles of Appendix 5 of 'Planning for Bush Fire Protection 2006':

- Suitable impervious areas are provided immediately surrounding the building such as courtyards, paths and driveways.
- Grassed areas, mowed lawns or ground cover plantings are provided in close proximity to the building.
- Planting is limited in the immediate vicinity of the building.
- Planting does not provide a continuous canopy to the building (i.e. trees or shrubs should be isolated or located in small clusters).
- Landscape species are chosen in consideration needs of the estimated size of the plant at maturity.
- Species are avoided that have rough fibrous bark, or which keep/shed bark in long strips or retain dead material in their canopies.
- Smooth bark species of tree are chosen which generally do not carry a fire up the bark into the crown.
- Planting of deciduous species is avoided which may increase fuel at surface/ ground level (i.e. leaf litter).
- Climbing species are avoided to walls and pergolas.
- Combustible materials such as woodchips/mulch and flammable fuel are stored away from the building.
- Combustible structures such as garden sheds, pergolas and materials such timber garden furniture are located way from the building.
- Low flammability vegetation species are used.

For any queries regarding this correspondence, please contact Alastair Patton on 1300 NSW RFS.

Yours sincerely,

Nika Fomin
Manager Planning & Environment Services
Planning and Environment Services