

## Compliance Certificate

Date: 5<sup>th</sup> July, 2019 Job No. 190714  
Client: Novam Design Studio Engineer: David Hunter  
**Site: 15 Wareham Crescent, Frenchs Forest**

David Hunter of Northern Beaches Consulting Engineers P/L inspected the northern and eastern elevation brickwork on the 5<sup>th</sup> July, 2019. The purpose of the inspection was to verify compliance of the current brickwork to the required fire rating of 60/60/60.

The details of the brickwork wall are:

- Wall height – 2500mm
- Wall width – 110mm brickwork with 120x230 engaged piers at 1800mm centres
- Wall is restrained at top and bottom
- Brickwork core ratio is approximately 15%

We hereby certify that the brickwork wall is compliant with the required rating of 60/60/60 in accordance with section 6 of Australian Standard AS 3700.

This certificate does not relate to and we assume no responsibility for the certification of any structural or other elements that have not been inspected by the companies' representatives or are not referred to in this certificate.

We trust that this certificate meets with your requirements. Please contact the author if further clarification is required.

### **NORTHERN BEACHES CONSULTING ENGINEERS P/L**



**David Hunter**  
BE CPEng NER

X:\Synergy\Projects\190714 15 WAREHAM CRESCENT, FRENCHS FOREST\ENG Design\SC001.docx