

<b>Sent:</b>	11/07/2022 10:23:38 AM
<b>Subject:</b>	NSW RFS Determination - Your Reference - CNR-40883 DA2022/0885
<b>Attachments:</b>	DA20220609008430-Original-1 - 11-07-2022 09_34_46 - Determination Letter.pdf;



## NSW RURAL FIRE SERVICE

**Attention:** Northern Beaches Council

**Your Reference:** CNR-40883 DA2022/0885

**Application Details:** s4.14 – Other – Original

**Site Address:**

82 Binburra Avenue Avalon Beach 2107

Please find attached correspondence relating to the above development.

Should you wish to discuss this matter please contact Jason Hulston on 1300 NSW RFS and quote DA20220609008430-Original-1.



**Planning and Environment Services**

**NSW RURAL FIRE SERVICE**

Locked Bag 17 Granville NSW 2142

**P** 1300 NSW RFS **E** [records@rfs.nsw.gov.au](mailto:records@rfs.nsw.gov.au)

[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au) | [www.facebook.com/nswrfs](https://www.facebook.com/nswrfs) | [www.twitter.com/nswrfs](https://www.twitter.com/nswrfs)

**PREPARE. ACT. SURVIVE.**



## NSW RURAL FIRE SERVICE

Northern Beaches Council  
PO Box 882  
MONA VALE NSW 1660

Your reference: CNR-40883 DA2022/0885  
Our reference: DA20220609008430-Original-1

**ATTENTION:** Northern Beaches Council

Date: Monday 11 July 2022

Dear Sir/Madam,

**Development Application**  
**s4.14 - Other - Single Dwelling - Alterations & Additions**  
**82 Binburra Avenue Avalon Beach 2107, 30//DP22275**

I refer to your correspondence dated 09/06/2022 seeking advice regarding bush fire protection for the above Development Application in accordance with section 4.14 of the *Environmental Planning and Assessment Act 1979*.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted and provides the following recommended conditions:

### Asset Protection Zones

***The intent of measures is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting fire fighting activities. To achieve this, the following conditions shall apply:***

1. From the start of building works, the property around the building must be managed as an inner protection area (IPA) for a distance of 9 metres or to the property boundary where this can not be achieved in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*. When establishing and maintaining an IPA the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover;
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.

#### Postal address

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

#### Street address

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555  
F (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)

- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed.

### **Construction Standards**

***The intent of measures is that buildings are designed and constructed to withstand the potential impacts of bush fire attack. To achieve this, the following conditions shall apply:***

2. New construction must comply with Sections 3 and 9 (BAL FZ) of Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas* – 2014 as appropriate and Section 7.5 of *Planning for Bush Fire Protection* 2019.

### **Landscaping Assessment**

***The intent of measures is for landscaping. To achieve this, the following conditions shall apply:***

3. Landscaping within the required asset protection zone must comply with Appendix 4 of *Planning for Bush Fire Protection* 2019. In this regard, the following principles are to be incorporated:

- A minimum 1 metre wide area (or to the property boundary where the setbacks are less than 1 metre), suitable for pedestrian traffic, must be provided around the immediate curtilage of the building;
- Planting is limited in the immediate vicinity of the building;
- Planting does not provide a continuous canopy to the building (i.e. trees or shrubs are isolated or located in small clusters);
- Landscape species are chosen to ensure tree canopy cover is less than 15% (IPA), and less than 30% (OPA) at maturity and trees do not touch or overhang buildings;
- Avoid species with rough fibrous bark, or which retain/shed bark in long strips or retain dead material in their canopies;
- Use smooth bark species of trees species which generally do not carry a fire up the bark into the crown;
- Avoid planting of deciduous species that may increase fuel at surface/ ground level (i.e. leaf litter);
- Avoid climbing species to walls and pergolas;
- Locate combustible materials such as woodchips/mulch, flammable fuel stores away from the building;
- Locate combustible structures such as garden sheds, pergolas and materials such as timber garden furniture away from the building; and
- Low flammability vegetation species are used.

For any queries regarding this correspondence, please contact Jason Hulston on 1300 NSW RFS.

Yours sincerely,

Adam Small

**A/Manager - Planning & Environment Services (East)  
Built & Natural Environment**