

Water Management Referral Response

Application Number:	DA2020/0436
Date:	22/05/2020
To:	Claire Ryan
Land to be developed (Address):	Lot 11 DP 270907 , 8 Baz Retreat WARRIEWOOD NSW 2102 Lot 10 DP 270907 , 9 Baz Retreat WARRIEWOOD NSW 2102

Reasons for referral

Council's Water Management Officers are required to consider the likely impacts.

Officer comments

This application has been assessed for compliance with the Water Management Report for the subdivision of 29-31 Warriewood Road, prepared by Civil Cert and dated 1/1/2018. The application is recommended for approval.

Site coverage is less than the maximum 65% allowed under the WMR and the stormwater plan prepared by Ibrahim Stormwater Consultants meets requirements.

Care must be taken with sediment and erosion controls to prevent sediment entering the stormwater network and impacting the bio-retention basin on the site, which will be responsibility of the property owners to clean.

Council proactively regulates construction sites for sediment management.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Water Management Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Installation and Maintenance of Sediment and Erosion Controls

Council proactively regulates construction sites for sediment management.

Sediment and erosion controls must be installed in accordance with Landcom's 'Managing Urban Stormwater: Soils and Construction' (2004) and the Erosion and Sediment Control Plan prepared by Nastasi and Associates prior to commencement of any other works on site.

Erosion and sediment controls are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and vegetation cover has been re-established across 70 percent of the site, and the



remaining areas have been stabilised with ongoing measures such as jute mesh or matting.

The discharge of sediment-laden waters from the site may result in clean-up orders and/or fines under Council's Compliance and Enforcement Policy and legislation including Protection of the Environment Operations Act 1997 and Contaminated Lands Act 1997.

Reason: Protection of the receiving environment