

## Landscape Referral Response

<b>Application Number:</b>	DA2020/0305
<b>Date:</b>	06/04/2020
<b>Responsible Officer:</b>	Gareth David
<b>Land to be developed (Address):</b>	Lot 3 DP 219898 , 13 Capua Place AVALON BEACH NSW 2107

### Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

### Officer comments

The development application seeks approval for alterations and additions to an existing residence.

Council's Landscape Referral section has assessed the proposal against the following Pittwater 21 DCP Controls:

B4.22 Preservation of Trees and Bushland Vegetation

C1.1 Landscaping

D1 Avalon Beach Locality

The site contains existing trees and vegetation. As described in the Statement of Environmental Effects, all vegetation remains unaffected by the works, with the proposed works unto existing hardstand areas. The proposal in terms of landscape outcome is acceptable subject to the protection of trees and vegetation in proximity to the development works.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Landscape Conditions:

#### **CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

#### **Tree and vegetation protection**

- a) Existing trees and vegetation shall be retained and protected, including:
- i) all trees and vegetation within the site as shown on the Survey Plan, excluding exempt vegetation under the relevant planning instruments of legislation,
  - ii) all trees and vegetation located on adjoining properties,
  - iii) all road reserve trees and vegetation,

b) Tree protection shall be generally undertaken as follows:

- i) all tree protection shall be in accordance with AS4970- 2009 Protection of Trees on Development Sites,
- ii) removal of existing tree roots greater than 25mm is not permitted without consultation with a qualified AQF minimum Level 5 Arborist,
- iii) existing ground levels shall remain under the tree protection zone of trees to be retained, unless authorised by a qualified AQF minimum Level 5 Arborist,
- iv) any tree roots exposed during excavation with a diameter greater than 25mm within the tree protection zone must be assessed by a qualified AQF minimum Level 5 Arborist. Details including photographic evidence of works undertaken shall be submitted to the Certifying Authority,
- v) to minimise the impact on trees and vegetation to be retained and protected, no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,
- vi) no tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified AQF minimum Level 5 Arborist on site,
- vii) all structures are to bridge tree roots greater than 25mm diameter unless directed by a qualified AQF minimum Level 5 Arborist on site,
- viii) excavation for stormwater lines and all other utility services is not permitted within the tree protection zone, without consultation with a a qualified AQF minimum Level 5 Arborist, including advice on root protection measures,
- ix) should either or all of vi), vii) and viii) occur during site establishment and construction works, a qualified AQF minimum Level 5 Arborist shall provide recommendations for tree protection measures. Details including photographic evidence of works undertaken shall be submitted by the Arborist to the Certifying Authority,
- x) any temporary access to, or location of scaffolding within the tree protection zone of a protected tree or any other tree to be retained during the construction works, is to be undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of AS 4970-2009,
- xi) tree pruning to enable construction shall not exceed 10% of any tree canopy, and shall be in accordance with AS4373-2009 Pruning of Amenity Trees.

c) All protected trees under a)i are to be retained for the life of the development, or for their safe natural life. Trees that die or are removed by approval must be replaced with a locally native canopy tree.

Reason: to retain and protect significant planting on development and adjoining sites.