

Landscape Referral Response

Application Number:	DA2019/1416
Date:	24/01/2020
Responsible Officer:	Kevin Short
Land to be developed (Address):	Lot 3 DP 241969 , 32 Monserra Road ALLAMBIE HEIGHTS NSW 2100

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The plans indicate the removal of one street tree to accommodate the new driveway crossover on Monserra Road. The tree is not considered significant and no objections are raised subject to conditions.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Tree protection

- (a) Existing trees which must be retained
 - i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
 - ii) Trees located on adjoining land
- (b) Tree protection
 - i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
 - ii) All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by a qualified Arborist on site.
 - iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
 - iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees

v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

Tree removal within the road reserve

i) This consent includes approval to remove one street tree located in the Monserra Road road reserve to accommodate the new driveway crossover:

ii) Removal of approved tree in the road reserve shall only be undertaken by a Council approved tree contractor.

iii) Details of currently approved tree contractors can be obtained from Northern Beaches Council Public Trees Section prior to removal.

Reason: Public liability