

## **Waste Referral Response**

Application Number:	DA2020/1597	
Date:	12/05/2021	

Date:	12/05/2021
То:	Anne-Marie Young
Land to be developed (Address): Lot 25 DP 7002 , 67 Pacific Parade DEE WHY NSW	

#### Reasons for referral

This application seeks consent for the following:

- new residential works with three or more dwellings. (RFB's, townhouses, seniors living, questhouses, etc). or
- mixed use developments containing three or more residential dwellings. or
- new subdivisions of three or more lots. (Private road and public road subdivisions) or

And as such, Councils Waste Management Officers are required to consider the likely impacts on drainage regimes.

#### Officer comments

**Waste Management Updated Assessment** (Amended master plans received 4 May 2021) Proposal is approved with conditions

Waste Management Assessment.

Recommendation - Refusal

Specifically:

1) The bin storage is too small to contain the required number of bins.

It is unacceptable to double/triple stack the bins.

Each row of bins must be accessible by an isle a minimum of 1 metre wide.

A simple redesign of the bin storage room/s in the current location would resolve this issue.

2) The use of bi-fold doors to screen the bins from view.

It is suggested that these type of doors not be used in this application.

Previous experience with these doors shows that the floor track very quickly fills with debris causing the doors to jamb.

Also depending on the type of floor track used impact damage by the bin wheels may render the doors unusable in a short space of time.

Ray Creer

Waste Services Officer

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### **Recommended Waste Conditions:**

DA2020/1597 Page 1 of 3



## CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

### Waste and Recycling Requirements

Details demonstrating compliance with Northern Beaches Waste Management Guidelines, are to be submitted to and approved by the Certifying Authority prior to the issue of any Construction Certificate.

Note: If the proposal, when compliant with the Northern Beaches Waste Management Guidelines, causes inconsistencies with other parts of the approval i.e. architectural or landscaped plans, a modification(s) to the development may be required.

Reason: To ensure adequate and appropriate waste and recycling facilities are provided.

## CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

### Waste/Recycling Requirements (Waste Plan Submitted)

During demolition and/or construction the proposal/works shall be generally consistent with the submitted Waste Management Plan titled dated 25 November 2020.

Reason: To ensure waste is minimised and adequate and appropriate waste and recycling facilities are provided.

## **Waste/Recycling Requirements (Materials)**

During demolition and/or construction the following materials are to be separated for recycling: timber, bricks, tiles, plasterboard, metal, concrete, and evidence of disposal for recycling is to be retained on site.

Reason: To ensure waste is minimised and recovered for recycling where possible.

# CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

### **Garbage and Recycling Facilities**

All internal walls of the waste rooms shall be rendered to a smooth surface, coved at the floor/wall intersection, graded and appropriately drained to the sewer with a tap in close proximity to facilitate cleaning.

Waste room floors shall be graded and drained to an approved Sydney Water drainage system.

Waste rooms shall be clear of any other services or utilities infrastructure such as gas, electricity air-conditioning, plumbing, piping ducting or equipment.

Reason: To prevent pollution of the environment, provide a safe workplace for contractors and residents and to protect the amenity of the area.

### **Waste and Recycling Facilities Certificate of Compliance**

The proposal shall be constructed in accordance with the Northern Beaches Waste Management Guidelines

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

DA2020/1597 Page 2 of 3



Reason: To ensure waste and recycling facilities are provided.

### **Waste/Recycling Compliance Documentation**

Evidence of disposal for recycling from the construction/demolition works shall be submitted to the Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To ensure waste is minimised and recycled.

### **Positive Covenant for Council and Contractor Indemnity**

A positive covenant shall be created on the title of the land prior to the issue of an Interim/Final Occupation Certificate requiring the proprietor of the land to provide access to the waste storage facilities. The terms of the positive covenant are to be prepared to Council's requirements, (Appendix E of the Waste Management Guidelines), at the applicant's expense and endorsed by Council prior to lodgement with NSW Land Registry Services. Northern Beaches Council shall be nominated as the party to release, vary or modify such covenant.

Reason: To ensure ongoing access for servicing of waste facilities.

## **Authorisation of Legal Documentation Required for Waste Services**

The original completed request form (NSW Land Registry Services form 13PC) must be submitted to Council for authorisation prior to the issue of the Interim/Final Occupation Certificate. A copy of the work-as-executed plan (details overdrawn on a copy of the approved plan) must be included with the above submission. Where required by Council or the Certifying Authority, a Compliance Certificate shall also be provided in the submission to Council.

If Council is to issue the Compliance Certificate for these works, the fee is to be in accordance with Council's Fees and Charges.

Reason: To create encumbrances on the land.

## ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

## Ongoing Conditions for Bulky Goods storage area

The Bulky Goods storage area is a designated area to accommodate bulky items.

The area must not be used to store any other items and must be clear of any service and utilities infrastructure and related activities.

Occupants will be required to self-present bulky goods kerbside.

Reason: To ensure an adequate and appropriate dedicated bulky goods storage area is provided.

DA2020/1597 Page 3 of 3