

Tuesday, 2 April 2024



**Client:** Name: Statewide Project Management Pty Ltd  
Address: Suit 3/79  
Alexander Street,  
Crowns Nest NSW 2065.

4/852 Old Princes Hwy,  
Sutherland NSW 2232  
Telephone 0295452348  
[admin@c-level.com.au](mailto:admin@c-level.com.au)  
[www.c-level.com.au](http://www.c-level.com.au)

**Attn:** Brent Jones

ABN 17 627 581 837

**Re: External Lighting Design**

**Project: Flower Power Garden Centre Terry Hills**

C-Level was engaged to provide an External lighting design including full obtrusive & spill lighting calculations. The external lighting calculation completed with AGI-32 software & referenced as CLE-2305-LUX-001-P2, which demonstrates compliance with:

- AS1158.3.1:2020
- AS4282:2019 (Category A3)
- AS1680.5:2012

The current Architectural plans would require minor coordination adjustments to the external lighting design, however we have reviewed & confirm that these minor adjustments would not be detrimental to any of the levels completed with the current calculation or the Australian Standard requirements noted above.

The letter has been provided by the engineers below; please use the contact details should any further details or information be required.

**Cameron Foster**  
*Electrical – Project Director*

A handwritten signature in black ink, appearing to read 'C Foster', written over a light blue horizontal line.

E: [cfoster@c-level.com.au](mailto:cfoster@c-level.com.au)  
P: 02 9545 2348, 0402 604 889

**Mahela Gunarathna**  
*Electrical - Engineer*

A handwritten signature in black ink, appearing to read 'Mahela Gunarathna', written over a light blue horizontal line.

E: [mgunarathna@c-level.com.au](mailto:mgunarathna@c-level.com.au)  
P: 02 9545 2348