

DEVELOPMENT APPLICATION ASSESSMENT REPORT

| | |
|----------------------------|-------------|
| Application Number: | DA2024/0870 |
|----------------------------|-------------|

| | |
|---|--|
| Responsible Officer: | Reeve Cocks |
| Land to be developed (Address): | Lot 1 DP 91180, 22 Abernethy Street SEAFORTH NSW 2092 Lot LIC 30003223, 22 Abernethy Street SEAFORTH NSW 2092 |
| Proposed Development: | Part demolition and construction of a lift with pathway connection between a garage and dwelling |
| Zoning: | Manly LEP2013 - Land zoned C3 Environmental Management |
| Development Permissible: | Yes |
| Existing Use Rights: | No |
| Consent Authority: | Northern Beaches Council |
| Land and Environment Court Action: | No |
| Applicant: | Edwin John Hardy |

| | |
|----------------------------------|--------------------------|
| Application Lodged: | 09/07/2024 |
| Integrated Development: | No |
| Designated Development: | No |
| State Reporting Category: | Residential - Other |
| Notified: | 17/07/2024 to 31/07/2024 |
| Advertised: | Not Advertised |
| Submissions Received: | 2 |
| Clause 4.6 Variation: | Nil |
| Recommendation: | Approval |

| | |
|---------------------------------|---------------|
| Estimated Cost of Works: | \$ 242,000.00 |
|---------------------------------|---------------|

PROPOSED DEVELOPMENT IN DETAIL

The development seeks consent for Alterations and additions to residential development.

Specifically the following works:

- Construction of lift and walkway.
- Removal of two (2) trees (tree 4 and 11 as outlined in the provided arboricultural report)
- Excavation works up to a depth of 2.3 metres to accommodate lift and walkway.

ASSESSMENT INTRODUCTION

The application has been assessed in accordance with the requirements of the Environmental Planning and Assessment Act 1979 and the associated Regulations. In this regard:

- An assessment report and recommendation has been prepared (the subject of this report) taking into account all relevant provisions of the Environmental Planning and Assessment Act 1979, and the associated regulations;
- A site inspection was conducted and consideration has been given to the impacts of the development upon the subject site and adjoining, surrounding and nearby properties;
- Notification to adjoining and surrounding properties, advertisement (where required) and referral to relevant internal and external bodies in accordance with the Act, Regulations and relevant Development Control Plan;
- A review and consideration of all submissions made by the public and community interest groups in relation to the application;
- A review and consideration of all documentation provided with the application (up to the time of determination);
- A review and consideration of all referral comments provided by the relevant Council Officers, State Government Authorities/Agencies and Federal Government Authorities/Agencies on the proposal.

SUMMARY OF ASSESSMENT ISSUES

Manly Local Environmental Plan 2013 - 6.9 Foreshore scenic protection area
 Manly Development Control Plan - 3.4 Amenity (Views, Overshadowing, Overlooking /Privacy, Noise)
 Manly Development Control Plan - 4.4.5 Earthworks (Excavation and Filling)
 Manly Development Control Plan - 5.4.1 Foreshore Scenic Protection Area

SITE DESCRIPTION

| | |
|-----------------------------------|---|
| Property Description: | Lot 1 DP 91180 , 22 Abernethy Street SEAFORTH NSW 2092 Lot LIC 30003223 , 22 Abernethy Street SEAFORTH NSW 2092 |
| Detailed Site Description: | <p>The subject site consists of one (1) allotment located on the western side of Abernethy Street.</p> <p>The site is regular in shape with a frontage of 14.45m along Abernethy Street and a depth of 122.2m. The site has an area of 1733m² (by title).</p> <p>The site is located within the C3 Environmental Management zone and accommodates an existing 3 storey residential dwelling house.</p> <p>The site slopes from the eastern (street) side boundary to the western waterfront boundary with an approximate height difference of 54 metres across the site. The site additionally has a minor cross fall from north to south of approximately 1</p> |

metre.

The site has multiple mature trees, medium shrubs and rock outcrops that provide amenity and character to the site. The development proposes the removal of 2 trees, one *Rothmannia globosa* and one *Strelitzia nicolai*. As noted in Council's Landscape Referral, "*based on existing heights both trees are exempt from requiring Council consent for management or removal.*"

Detailed Description of Adjoining/Surrounding Development

Adjoining and surrounding development is characterised by one, two, and three storey dwelling houses.

Map:



SITE HISTORY

The land has been used for residential purposes for an extended period of time. A search of Council's records has revealed the following relevant history:

Development Application DA 320/2016

Alterations and additions to the existing dwelling house. (Approved - 16 March 2017)

Section 455 Modifications Mod2018/0378

Modification of Development Consent DA0320/2016 granted for alterations and additions to the existing dwelling house (Approved - 17 September 2018)

ENVIRONMENTAL PLANNING AND ASSESSMENT ACT, 1979 (EPAA)

The relevant matters for consideration under the Environmental Planning and Assessment Act, 1979, are:

| Section 4.15 Matters for Consideration | Comments |
|---|--|
| Section 4.15 (1) (a)(i) – Provisions of any environmental planning instrument | See discussion on “Environmental Planning Instruments” in this report. |
| Section 4.15 (1) (a)(ii) – Provisions of any draft environmental planning instrument | There are no current draft environmental planning instruments. |
| Section 4.15 (1) (a)(iii) – Provisions of any development control plan | Manly Development Control Plan applies to this proposal. |
| Section 4.15 (1) (a)(iiiia) – Provisions of any planning agreement | None applicable. |
| Section 4.15 (1) (a)(iv) – Provisions of the Environmental Planning and Assessment Regulation 2021 (EP&A Regulation 2021) | <p><u>Part 4, Division 2</u> of the EP&A Regulation 2021 requires the consent authority to consider "Prescribed conditions" of development consent. These matters have been addressed via a condition of consent.</p> <p><u>Clause 29</u> of the EP&A Regulation 2021 requires the submission of a design verification certificate from the building designer at lodgement of the development application. This clause is not relevant to this application.</p> <p><u>Clauses 36 and 94</u> of the EP&A Regulation 2021 allow Council to request additional information. No additional information was requested in this case.</p> <p><u>Clause 61</u> of the EP&A Regulation 2021 requires the consent authority to consider AS 2601 - 1991: The Demolition of Structures. This matter has been addressed via a condition of consent.</p> <p><u>Clauses 62 and/or 64</u> of the EP&A Regulation 2021 requires the consent authority to consider the upgrading of a building (including fire safety upgrade of development). This matter has been addressed via a condition of consent.</p> <p><u>Clause 69</u> of the EP&A Regulation 2021 requires the consent authority to consider insurance requirements under the Home Building Act 1989. This matter has been addressed via a condition of consent.</p> <p><u>Clause 69</u> of the EP&A Regulation 2021 requires the consent authority to consider the provisions of the Building Code of Australia (BCA). This matter has been addressed via a condition of consent.</p> |
| Section 4.15 (1) (b) – the likely impacts of the development, including environmental impacts on the natural and built environment and social | (i) Environmental Impact The environmental impacts of the proposed development on the natural and built environment are addressed under the Manly Development Control Plan section in this report. |

| Section 4.15 Matters for Consideration | Comments |
|--|---|
| and economic impacts in the locality | <p>(ii) Social Impact The proposed development will not have a detrimental social impact in the locality considering the character of the proposal.</p> <p>(iii) Economic Impact The proposed development will not have a detrimental economic impact on the locality considering the nature of the existing and proposed land use.</p> |
| Section 4.15 (1) (c) – the suitability of the site for the development | The site is considered suitable for the proposed development. |
| Section 4.15 (1) (d) – any submissions made in accordance with the EPA Act or EPA Regs | See discussion on “Notification & Submissions Received” in this report. |
| Section 4.15 (1) (e) – the public interest | No matters have arisen in this assessment that would justify the refusal of the application in the public interest. |

EXISTING USE RIGHTS

Existing Use Rights are not applicable to this application.

BUSHFIRE PRONE LAND

The site is classified as bush fire prone land. Section 4.14 of the Environmental Planning and Assessment Act 1979 requires Council to be satisfied that the development conforms to the specifications and requirements of the version (as prescribed by the regulations) of the document entitled Planning for Bush Fire Protection.

A Bush Fire Report was submitted with the application that included a certificate (prepared by Eco Logical Australia, dated August 2018) stating that the development conforms to the relevant specifications and requirements within Planning for Bush Fire Protection. The recommendations of the Bush Fire Report have been included as conditions of consent.

NOTIFICATION & SUBMISSIONS RECEIVED

The subject application has been publicly exhibited from 17/07/2024 to 31/07/2024 in accordance with the Environmental Planning and Assessment Act 1979, Environmental Planning and Assessment Regulation 2021 and the Community Participation Plan.

As a result of the public exhibition process council is in receipt of 2 submission/s from:

| Name: | Address: |
|---------------------------|---------------------------------------|
| Mr Peter Douglas Woodhead | 24 Abernethy Street SEAFORTH NSW 2092 |
| Mr Alan Neil Johnson | 17 Abernethy Street SEAFORTH NSW 2092 |

The following issues were raised in the submissions:

- Traffic Management Plan

The above issues are addressed as follows:

- **Traffic Management Plan**

The submissions raised concerns that the street (Abernethy Street) and adjoining street (Jenner Street) will likely be impacted by the multiple developments being conducted as assessing this application.

Comment:

The street (Abernethy) narrows and may become congested due to the works proposed.

Council has included a condition of consent for the applicant to provide a traffic management plan to mitigate the impacts of multiple developments within the street. It is considered that this condition satisfies the concerns raised.

REFERRALS

| Internal Referral Body | Comments |
|----------------------------------|---|
| Landscape Officer | The application is for a proposed construction of a lift adjoining the existing garage and a new covered walkway. There are two existing exotic trees that are located within the proposed footprint of the proposed works, being tree 4 (Tree Gardenia) and tree 11 (Strelitzia), and Landscape Referral raise no concerns with the proposed tree removals noting that based on existing heights both trees are exempt from requiring Council consent for management or removal. The recommendations of the Arboricultural Impact Assessment report are noted including tree protection measures for retained trees and conditions shall be imposed. |
| NECC (Bushland and Biodiversity) | <p>The comments in this referral relate to the following applicable controls and provisions:</p> <ul style="list-style-type: none"> • SEPP (resilience and hazards) 2021 - Coastal Environment Area • Manly LEP - Clause 6.5 Terrestrial Biodiversity <p>The proposal will require the removal of two trees (tree 4 and tree 10) which are considered exempt as they are under 5 metres and is unlikely to impact native flora and fauna.</p> <p>The development is designed, sited and will be managed to avoid any significant adverse environmental impact.</p> |

| External Referral Body | Comments |
|---|--|
| Ausgrid - SEPP (Transport and Infrastructure) 2021, s2.48 | The proposal was referred to Ausgrid who provided a response stating that the proposal is acceptable subject to compliance with the relevant Ausgrid Network Standards and SafeWork NSW Codes of Practice. These recommendations will be included as a condition of consent. |
| Aboriginal Heritage Office | <p>No sites are recorded in the current development area and the area has been subject to previous disturbance reducing the likelihood of surviving unrecorded Aboriginal sites.</p> <p>Given the above, the Aboriginal Heritage Office considers that there are no Aboriginal heritage issues for the proposed development.</p> <p>Under the National Parks and Wildlife Act 1974 (NPW Act) all Aboriginal objects are protected. Should any Aboriginal Cultural Heritage items be uncovered during earthworks, works should cease in the area and the Aboriginal Heritage Office assess the finds. Under Section 89a of the NPW Act should the objects be found to be Aboriginal, Heritage NSW and the Metropolitan Local Aboriginal Land Council (MLALC) should be contacted.</p> |

ENVIRONMENTAL PLANNING INSTRUMENTS (EPIS)*

All, Environmental Planning Instruments (SEPPs and LEPs), Development Controls Plans and Council Policies have been considered in the merit assessment of this application.

In this regard, whilst all provisions of each Environmental Planning Instruments (SEPPs and LEPs), Development Controls Plans and Council Policies have been considered in the assessment, many provisions contained within the document are not relevant or are enacting, definitions and operational provisions which the proposal is considered to be acceptable against.

As such, an assessment is provided against the controls relevant to the merit consideration of the application hereunder.

State Environmental Planning Policies (SEPPs) and State Regional Environmental Plans (SREPs)

SEPP (Sustainable Buildings) 2022

A BASIX certificate has been submitted with the application (see Certificate No. A1742271 dated 3 April 2024).

A condition has been included in the recommendation of this report requiring compliance with the commitments indicated in the BASIX Certificate.

SEPP (Transport and Infrastructure) 2021

Ausgrid

Section 2.48 of Chapter 2 requires the Consent Authority to consider any development application (or an application for modification of consent) for any development carried out:

- within or immediately adjacent to an easement for electricity purposes (whether or not the electricity infrastructure exists).
- immediately adjacent to an electricity substation.
- within 5.0m of an overhead power line.
- includes installation of a swimming pool any part of which is: within 30m of a structure supporting an overhead electricity transmission line and/or within 5.0m of an overhead electricity power line.

Comment:

The proposal was referred to Ausgrid who raised no objections, subject to conditions which have been included in the recommendation of this report.

SEPP (Resilience and Hazards) 2021

Chapter 2 – Coastal Management

The site is subject to Chapter 2 of the SEPP. Accordingly, an assessment under Chapter 2 has been carried out as follows:

Division 3 Coastal environment area

2.10 Development on land within the coastal environment area

- 1) Development consent must not be granted to development on land that is within the coastal environment area unless the consent authority has considered whether the proposed development is likely to cause an adverse impact on the following:
 - a) the integrity and resilience of the biophysical, hydrological (surface and groundwater) and ecological environment,
 - b) coastal environmental values and natural coastal processes,
 - c) the water quality of the marine estate (within the meaning of the Marine Estate Management Act 2014), in particular, the cumulative impacts of the proposed development on any of the sensitive coastal lakes identified in Schedule 1,
 - d) marine vegetation, native vegetation and fauna and their habitats, undeveloped headlands and rock platforms,
 - e) existing public open space and safe access to and along the foreshore, beach, headland or rock platform for members of the public, including persons with a disability,
 - f) Aboriginal cultural heritage, practices and places,
 - g) the use of the surf zone.

Comment:

It is considered by Council that the proposed development is not likely to have an adverse impact on any items raised in subsection (1) above. The development represents a reasonable and orderly development of the site which has taken into consideration potential impacts on environmental factors.

- 2) Development consent must not be granted to development on land to which this clause applies unless the consent authority is satisfied that:
- a) the development is designed, sited and will be managed to avoid an adverse impact referred to in subsection (1), or
 - b) if that impact cannot be reasonably avoided—the development is designed, sited and will be managed to minimise that impact, or
 - c) if that impact cannot be minimised—the development will be managed to mitigate that impact.

Comment:

Council is satisfied that the development is designed, sited and will be managed to avoid an adverse impact referred to in subsection (1).

Division 4 Coastal use area

2.11 Development on land within the coastal use area

- 1) Development consent must not be granted to development on land that is within the coastal use area unless the consent authority:
- a) has considered whether the proposed development is likely to cause an adverse impact on the following:
 - i) existing, safe access to and along the foreshore, beach, headland or rock
 - ii) platform for members of the public, including persons with a disability,
 - iii) overshadowing, wind funnelling and the loss of views from public places to
 - iv) foreshores,
 - v) the visual amenity and scenic qualities of the coast, including coastal headlands, Aboriginal cultural heritage, practices and places, cultural and built environment heritage, and
 - b) is satisfied that:
 - i) the development is designed, sited and will be managed to avoid an
 - ii) adverse impact referred to in paragraph (a), or
 - iii) if that impact cannot be reasonably avoided—the development is designed, sited and will be managed to minimise that impact, or if that impact cannot be minimised—the development will be managed to mitigate that impact, and
 - c) has taken into account the surrounding coastal and built environment, and the bulk, scale and size of the proposed development.

Comment:

It is considered by Council that the development is not likely to result in an adverse impact on items raised in paragraph (a). Council is satisfied that the development is designed, sited and will be managed to avoid an adverse impact referred to in paragraph (a).

Division 5 General

2.12 Development in coastal zone generally—development not to increase risk of coastal hazards

Development consent must not be granted to development on land within the coastal zone unless the consent authority is satisfied that the proposed development is not likely to cause increased risk of coastal hazards on that land or other land.

Comment:

The development is located significantly away from the foreshore and does not propose to remove, alter or impact threatened flora or valuable site features. Council is satisfied that the development is not likely to increase risk of coastal hazards on the land or other land.

2.13 Development in coastal zone generally—coastal management programs to be considered

Development consent must not be granted to development on land within the coastal zone unless the consent authority has taken into consideration the relevant provisions of any certified coastal management program that applies to the land.

Comment:

The Northern Beaches Council currently has two (2) active Coastal Zone Management Plans (CZMP's), CZMP for Bilgola Beach (Mona Vale) and CZMP for Collaroy-Narrabeen Beach and Fishermans Beach 2016. No CZMP's relate to the subject site.

As such, it is considered that the application complies with the requirements of Chapter 2 of the State Environmental Planning Policy (Resilience and Hazards) 2021.

Chapter 4 – Remediation of Land

Sub-section 4.6 (1)(a) of Chapter 4 requires the Consent Authority to consider whether land is contaminated. Council records indicate that the subject site has been used for residential purposes for a significant period of time with no prior land uses. In this regard it is considered that the site poses no risk of contamination and therefore, no further consideration is required under sub-section 4.6 (1)(b) and (c) of this Chapter and the land is considered to be suitable for the residential land use.

Manly Local Environmental Plan 2013

| | |
|--|-----|
| Is the development permissible? | Yes |
| After consideration of the merits of the proposal, is the development consistent with: | |
| aims of the LEP? | Yes |
| zone objectives of the LEP? | Yes |

Principal Development Standards

| Standard | Requirement | Proposed | % Variation | Complies |
|----------------------|-------------|----------|-------------|----------|
| Height of Buildings: | 8.5m | 6m | - | Yes |
| Floor Space Ratio | FSR: 0.40:1 | 0.17:1 | - | Yes |

Compliance Assessment

| Clause | Compliance with Requirements |
|--|------------------------------|
| 4.3 Height of buildings | Yes |
| 4.4 Floor space ratio | Yes |
| 4.5 Calculation of floor space ratio and site area | Yes |
| 5.7 Development below mean high water mark | Yes |
| 5.21 Flood planning | Yes |
| 6.2 Earthworks | Yes |
| 6.4 Stormwater management | Yes |
| 6.5 Terrestrial biodiversity | Yes |
| 6.8 Landslide risk | Yes |
| 6.9 Foreshore scenic protection area | Yes |
| 6.10 Limited development on foreshore area | Yes |
| 6.12 Essential services | Yes |

Detailed Assessment

6.9 Foreshore scenic protection area

Under this clause, development consent must not be granted to development on land to which this clause applies unless the consent authority has considered the following matters:

- (a) *impacts that are of detriment to the visual amenity of harbour or coastal foreshore, including overshadowing of the foreshore and any loss of views from a public place to the foreshore,*
- (b) *measures to protect and improve scenic qualities of the coastline,*
- (c) *suitability of development given its type, location and design and its relationship with and impact on the foreshore,*
- (d) *measures to reduce the potential for conflict between land-based and water-based coastal activities.*

Comment:

The proposed development will not be visible from the harbour or coastal foreshore and will have no impact on visual amenity. The coastline will not be impacted by the development and it is considered suitable for the site. The development will not cause conflict between land-based and water-based coastal activities.

Manly Development Control Plan

Built Form Controls

| Built Form Controls - Site Area: 1733m ² (by title) | Requirement | Proposed | % Variation* | Complies |
|--|--|----------|--------------|----------|
| 4.1.1.1 Residential Density and Dwelling Size | Density: 1 dwelling per 1150m ² | 1 | - | Yes |

| | | | | |
|--|---|---|---|-------------|
| 4.1.2.1 Wall Height | 8m (based on gradient 1:4 area I) | 7.6m (taken from excavated ground level) | - | Yes |
| 4.1.2.3 Roof Height | Height: 2.5m | - | - | Yes |
| | Pitch: maximum 35 degrees | 0 degrees | - | Yes |
| 4.1.4.1 Street Front Setbacks | Prevailing building line / 6m | 9.21m, consistent with prevailing setback | - | Yes |
| 4.1.4.2 Side Setbacks and Secondary Street Frontages | 2.53m (based on wall height) | (N) 6.43m | - | Yes |
| | | (S) 5.88m | - | Yes |
| 4.1.4.4 Rear Setbacks | 8m | 88.88m (from proposed works) | - | Yes |
| 4.1.4.6 Setback for development adjacent to LEP Zones RE1, RE2, E1 and E2 | 6m (common boundary) | >6m | - | Yes |
| | 8m (rear boundary) | >8m | - | Yes |
| 4.1.5.1 Minimum Residential Total Open Space Requirements Residential Open Space Area: OS4 | Open space 60%% of site area | 86% (1498m ²) | - | Yes |
| | Open space above ground 25% of total open space | 0% | - | Yes |
| 4.1.5.2 Landscaped Area | Landscaped area 40% of open space | 67% (1163m ²) | - | Yes |
| | 4 native trees | >4 trees (existing) | - | Yes |
| 4.1.5.3 Private Open Space | 18sqm per dwelling | >18m ² | - | Yes |
| 4.1.6.1 Parking Design and the Location of Garages, Carports or Hardstand Areas | Maximum 50% of frontage up to maximum 6.2m | - | - | as existing |
| Schedule 3 Parking and Access | Dwelling 2 spaces | - | - | as existing |

Compliance Assessment

| Clause | Compliance with Requirements | Consistency Aims/Objectives |
|---|------------------------------|-----------------------------|
| 3.1 Streetscapes and Townscapes | Yes | Yes |
| 3.1.1 Streetscape (Residential areas) | Yes | Yes |
| 3.3.1 Landscaping Design | Yes | Yes |
| 3.3.2 Preservation of Trees or Bushland Vegetation | Yes | Yes |
| 3.3.3 Footpath Tree Planting | Yes | Yes |
| 3.4 Amenity (Views, Overshadowing, Overlooking /Privacy, Noise) | Yes | Yes |
| 3.4.1 Sunlight Access and Overshadowing | Yes | Yes |
| 3.4.2 Privacy and Security | Yes | Yes |

| Clause | Compliance with Requirements | Consistency Aims/Objectives |
|--|------------------------------|-----------------------------|
| 3.4.3 Maintenance of Views | Yes | Yes |
| 3.4.4 Other Nuisance (Odour, Fumes etc.) | Yes | Yes |
| 3.5 Sustainability - (Greenhouse Energy Efficiency, Thermal Performance, and Water Sensitive Urban Design) | Yes | Yes |
| 3.5.1 Solar Access | Yes | Yes |
| 3.5.3 Ventilation | Yes | Yes |
| 3.5.4 Energy Efficient Appliances and Demand Reduction and Efficient Lighting (non-residential buildings) | Yes | Yes |
| 3.5.5 Landscaping | Yes | Yes |
| 3.5.7 Building Construction and Design | Yes | Yes |
| 3.6 Accessibility | Yes | Yes |
| 3.7 Stormwater Management | Yes | Yes |
| 3.8 Waste Management | Yes | Yes |
| 3.9 Mechanical Plant Equipment | Yes | Yes |
| 3.10 Safety and Security | Yes | Yes |
| 4.1 Residential Development Controls | Yes | Yes |
| 4.1.1 Dwelling Density, Dwelling Size and Subdivision | Yes | Yes |
| 4.1.1.1 Residential Density and Dwelling Size | Yes | Yes |
| 4.1.2 Height of Buildings (Incorporating Wall Height, Number of Storeys & Roof Height) | Yes | Yes |
| 4.1.3 Floor Space Ratio (FSR) | Yes | Yes |
| 4.1.4 Setbacks (front, side and rear) and Building Separation | Yes | Yes |
| 4.1.5 Open Space and Landscaping | Yes | Yes |
| 4.1.6 Parking, Vehicular Access and Loading (Including Bicycle Facilities) | Yes | Yes |
| 4.1.8 Development on Sloping Sites | Yes | Yes |
| 4.4.1 Demolition | Yes | Yes |
| 4.4.2 Alterations and Additions | Yes | Yes |
| 4.4.2 Awning supported from the ground | Yes | Yes |
| 4.4.5 Earthworks (Excavation and Filling) | No | Yes |
| 5 Special Character Areas and Sites | Yes | Yes |
| 5.4.1 Foreshore Scenic Protection Area | Yes | Yes |
| Schedule 1 – Maps accompanying the DCP | Yes | Yes |

Detailed Assessment

3.4 Amenity (Views, Overshadowing, Overlooking /Privacy, Noise)

The proposed development is not likely to result in unreasonable amenity impacts on adjoining and surrounding neighbours. Councils assessment did not identify any visual, acoustic, privacy, overshadowing, or noise impacts. One window is proposed to the lift which faces west towards the

main dwelling house. It is considered that this window will not result in amenity impacts given its orientation and association with the lift. The walkway is generally located at ground level and will not reduce the amenity of adjoining neighbours.

4.4.5 Earthworks (Excavation and Filling)

Description of non-compliance

Excavation works under section 4.4.5 of the Manly Development Control Plan are generally limited to 1 metre. The proposed lift and walkway will result in an excavation depth varying between 0 and 2.3 metres. It should be noted that the site slopes both from the front (east) to rear (west) and side (north) to side (south). The development has been designed to reduce the visual bulk and scale as viewed from adjoining properties and the public realm as well as to reflect the existing sloping topography on site.

Crozier geotechnical consultants have provided a geotechnical report on behalf of the applicant, assessing the potential hazards associated with the proposed excavation works. The recommendations made in the geotechnical report have been included as a condition of consent.

It is considered that the excavation works are a reasonable development of the site in this circumstance.

5.4.1 Foreshore Scenic Protection Area

The development does not propose any works within the foreshore scenic protection area (as identified by the foreshore building line). It is considered that the development will not have an unreasonable impact on the foreshore.

THREATENED SPECIES, POPULATIONS OR ECOLOGICAL COMMUNITIES

The proposal will not significantly affect threatened species, populations or ecological communities, or their habitats.

CRIME PREVENTION THROUGH ENVIRONMENTAL DESIGN

The proposal is consistent with the principles of Crime Prevention Through Environmental Design.

POLICY CONTROLS

Northern Beaches Section 7.12 Contributions Plan 2022

The proposal is subject to the application of Northern Beaches Section 7.12 Contributions Plan 2022.

A monetary contribution of \$2,420 is required for the provision of new and augmented public infrastructure. The contribution is calculated as 1% of the total development cost of \$242,000.

CONCLUSION

The site has been inspected and the application assessed having regard to all documentation submitted by the applicant and the provisions of:

- Environmental Planning and Assessment Act 1979;

- Environmental Planning and Assessment Regulation 2021;
- All relevant and draft Environmental Planning Instruments;
- Manly Local Environment Plan;
- Manly Development Control Plan; and
- Codes and Policies of Council.

This assessment has taken into consideration the submitted plans, Statement of Environmental Effects, all other documentation supporting the application and public submissions, and does not result in any unreasonable impacts on surrounding, adjoining, adjacent and nearby properties subject to the conditions contained within the recommendation.

In consideration of the proposal and the merit consideration of the development, the proposal is considered to be:

- Consistent with the objectives of the DCP
- Consistent with the zone objectives of the LEP
- Consistent with the aims of the LEP
- Consistent with the objectives of the relevant EPs
- Consistent with the objects of the Environmental Planning and Assessment Act 1979

It is considered that the proposed development satisfies the appropriate controls and that all processes and assessments have been satisfactorily addressed.

RECOMMENDATION

THAT Council as the consent authority grant Development Consent to DA2024/0870 for Part demolition and construction of a lift with pathway connection between a garage and dwelling on land at Lot 1 DP 91180, 22 Abernethy Street, SEAFORTH, Lot LIC 30003223, 22 Abernethy Street, SEAFORTH, subject to the conditions printed below:

Terms and Reasons for Conditions

Under section 88(1)(c) of the EP&A Regulation, the consent authority must provide the terms of all conditions and reasons for imposing the conditions other than the conditions prescribed under section 4.17(11) of the EP&A Act. The terms of the conditions and reasons are set out below.

GENERAL CONDITIONS

1. Approved Plans and Supporting Documentation

Development must be carried out in accordance with the following approved plans (stamped by Council) and supporting documentation, except where the conditions of this consent expressly require otherwise.

| Approved Plans | | | | |
|----------------|-----------------|-------------------------------|--------------------------------|--------------|
| Plan Number | Revision Number | Plan Title | Drawn By | Date of Plan |
| DA03.1 | 1 | Proposed Site Plan @ 1 To 500 | Designed 2 You Building Design | 4 April 2024 |

| | | | | |
|--------|---|---|--------------------------------|--------------|
| DA03.2 | 1 | Proposed Site Plan @ 1 To 200 | Designed 2 You Building Design | 4 April 2024 |
| DA04 | 1 | Existing / Demolition Plan - Garage Level | Designed 2 You Building Design | 4 April 2024 |
| DA05 | 1 | Proposed Garage Level Plan | Designed 2 You Building Design | 4 April 2024 |
| DA06 | 1 | Proposed Entry Level Plan | Designed 2 You Building Design | 4 April 2024 |
| DA07 | 1 | Proposed Roof Plan | Designed 2 You Building Design | 4 April 2024 |
| DA08 | 1 | Elevations | Designed 2 You Building Design | 4 April 2024 |
| DA09 | 1 | Elevations | Designed 2 You Building Design | 4 April 2024 |
| DA10 | 1 | Section A-A | Designed 2 You Building Design | 4 April 2024 |
| DA11 | 1 | External Finishes Schedule | Designed 2 You Building Design | 4 April 2024 |
| DA16 | 1 | Waste Management Plan / Sediment Erosion | Designed 2 You Building Design | 4 April 2024 |

| Approved Reports and Documentation | | | |
|---|-----------------------|----------------------------------|-------------------------|
| Document Title | Version Number | Prepared By | Date of Document |
| Waste Management Plan | - | Designed 2 You | 28 June 2024 |
| Basix Certificate | A1742271 | - | 4 April 2024 |
| Geotechnical Report | - | Crozier Geotechnical Consultants | 25 June 2024 |
| Bushfire Report | - | Eco Logical Australia | August 2018 |
| Biodiversity Report | - | Narla Environmental | December 2016 |
| Arboricultural Report | - | Designed 2 You | 13 June 2024 |

In the event of any inconsistency between the approved plans, reports and documentation, the approved plans prevail.

In the event of any inconsistency between the approved plans and a condition of this consent, the condition prevails.

Reason: To ensure all parties are aware of the approved plans and supporting documentation

that applies to the development.

2. Compliance with Other Department, Authority or Service Requirements

The development must be carried out in compliance with all recommendations and requirements, excluding general advice, within the following:

| Other Department, Authority or Service | EDMS Reference | Dated |
|--|---------------------------|--------------|
| Ausgrid | Ausgrid Referral Response | 16 July 2024 |

(NOTE: For a copy of the above referenced document/s, please see Application Tracking on Council's website www.northernbeaches.nsw.gov.au)

Reason: To ensure the work is carried out in accordance with the determination and the statutory requirements of other departments, authorities or bodies.

3. Prescribed conditions (Demolition):

(a) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:

- (i) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
- (ii) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

(b) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifier for the development to which the work relates (not being the Council) has given the Council written notice of the following information:

- (i) in the case of work for which a principal contractor is required to be appointed:
 - A. the name and licence number of the principal contractor, and
 - B. the name of the insurer by which the work is insured under Part 6 of that Act,
- (ii) in the case of work to be done by an owner-builder:
 - A. the name of the owner-builder, and
 - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifier for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.

(c) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:

- (i) protect and support the adjoining premises from possible damage from the excavation, and
- (ii) where necessary, underpin the adjoining premises to prevent any such damage.
- (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.

(iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

Reason: Legislative Requirement.

4. **Prescribed Conditions**

- (a) All building works must be carried out in accordance with the requirements of the Building Code of Australia (BCA).
- (b) BASIX affected development must comply with the schedule of BASIX commitments specified within the submitted BASIX Certificate (demonstrated compliance upon plans/specifications is required prior to the issue of the Construction Certificate);
- (c) A sign must be erected in a prominent position on any site on which building work, subdivision work or demolition work is being carried out:
 - (i) showing the name, address and telephone number of the Principal Certifier for the work, and
 - (ii) showing the name of the principal contractor (if any) for any building work and a telephone number on which that person may be contacted outside working hours, and
 - (iii) stating that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the building work, subdivision work or demolition work is being carried out, but must be removed when the work has been completed.

- (d) Residential building work within the meaning of the Home Building Act 1989 must not be carried out unless the Principal Certifier for the development to which the work relates (not being the Council) has given the Council written notice of the following information:
 - (i) in the case of work for which a principal contractor is required to be appointed:
 - A. the name and licence number of the principal contractor, and
 - B. the name of the insurer by which the work is insured under Part 6 of that Act,
 - (ii) in the case of work to be done by an owner-builder:
 - A. the name of the owner-builder, and
 - B. if the owner-builder is required to hold an owner-builder permit under that Act, the number of the owner-builder permit.

If arrangements for doing the residential building work are changed while the work is in progress so that the information notified under becomes out of date, further work must not be carried out unless the Principal Certifier for the development to which the work relates (not being the Council) has given the Council written notice of the updated information.

- (e) Development that involves an excavation that extends below the level of the base of the footings of a building on adjoining land, the person having the benefit of the development consent must, at the person's own expense:
 - (i) protect and support the adjoining premises from possible damage from the excavation, and
 - (ii) where necessary, underpin the adjoining premises to prevent any such damage.

- (iii) must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished.
- (iv) the owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this clause, whether carried out on the allotment of land being excavated or on the adjoining allotment of land.

In this clause, allotment of land includes a public road and any other public place.

Reason: Legislative requirement.

5. General requirements (Demolition):

(a) Unless authorised by Council:

Demolition and excavation works are restricted to:

- 8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

(b) At all times after the submission a Notice of Commencement to Council, a copy of the Development Consent is to remain onsite at all times until completion of demolition works. The consent shall be available for perusal of any Authorised Officer.

(c) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.

(d) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.

(e) The applicant shall bear the cost of all works that occur on Council's property.

(f) No building, demolition, excavation or material of any nature shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.

(g) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.

(h) All sound producing plant, equipment, machinery or fittings will not exceed more than 5dB(A) above the background level when measured from any property boundary and will comply with the Environment Protection Authority's NSW Industrial Noise Policy.)

(i) No trees or native shrubs or understorey vegetation on public property (footpaths, roads, reserves, etc.) or on the land to be developed shall be removed or damaged during construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.

6. General Requirements

(a) Unless authorised by Council:

Building construction and delivery of material hours are restricted to:

- 7.00 am to 5.00 pm inclusive Monday to Friday,
- 8.00 am to 1.00 pm inclusive on Saturday,
- No work on Sundays and Public Holidays.

Demolition and excavation works are restricted to:

- 8.00 am to 5.00 pm Monday to Friday only.

(Excavation work includes the use of any excavation machinery and the use of jackhammers, rock breakers, excavators, loaders and the like, regardless of whether the activities disturb or alter the natural state of the existing ground stratum or are breaking up/removing materials from the site).

- (b) Construction certificate plans are to be in accordance with all finished levels identified on approved plans. Notes attached to plans indicating tolerances to levels are not approved.
- (c) Should any asbestos be uncovered on site, its demolition and removal must be carried out in accordance with WorkCover requirements and the relevant Australian Standards.
- (d) At all times after the submission of the Notice of Commencement to Council, a copy of the Development Consent and Construction Certificate is to remain onsite at all times until the issue of an Occupation Certificate. The consent shall be available for perusal of any Authorised Officer.
- (e) Where demolition works have been completed and new construction works have not commenced within 4 weeks of the completion of the demolition works that area affected by the demolition works shall be fully stabilised and the site must be maintained in a safe and clean state until such time as new construction works commence.
- (f) Onsite toilet facilities (being either connected to the sewer or an accredited sewer management facility) for workers are to be provided for construction sites at a rate of 1 per 20 persons.
- (g) Prior to the release of the Construction Certificate, payment of the following is required:
 - i) Long Service Levy - Payment should be made to Service NSW (online or in person) or alternatively to Northern Beaches Council in person at a Customer Service Centre. Payment is not required where the value of the works is less than \$250,000. The Long Service Levy is calculated on 0.25% of the building and construction work. The levy rate and level in which it applies is subject to legislative change. The applicable fee at the time of payment of the Long Service Levy will apply.
 - ii) Section 7.11 or Section 7.12 Contributions Plan – Payment must be made to Northern Beaches Council. Where the subject land to which the development is proposed is subject to either a Section 7.11 or 7.12 Contributions Plan, any contribution to which the development is liable under the respective plan that applies is to be paid to Council. The outstanding contribution will be indexed at time of payment in accordance with the relevant Contributions Plan.

- iii) Housing and Productivity Contribution - Payment must be made on the NSW Planning Portal for development to which this contribution applies. The amount payable is subject to indexation at the time of payment.
- (h) The applicant shall bear the cost of all works associated with the development that occurs on Council's property.
- (i) No skip bins, building materials, demolition or excavation waste of any nature, and no hoist, plant or machinery (crane, concrete pump or lift) shall be placed on Council's footpaths, roadways, parks or grass verges without Council Approval.
- (j) Demolition materials and builders' wastes are to be removed to approved waste/recycling centres.
- (k) No trees or native shrubs or understorey vegetation on public property (footpaths, roads, reserves, etc.), on the land to be developed, or within adjoining properties, shall be removed or damaged during excavation or construction unless specifically approved in this consent including for the erection of any fences, hoardings or other temporary works.
- (l) Prior to the commencement of any development onsite for:
 - i) Building/s that are to be erected
 - ii) Building/s that are situated in the immediate vicinity of a public place and is dangerous to persons or property on or in the public place
 - iii) Building/s that are to be demolished
 - iv) For any work/s that is to be carried out
 - v) For any work/s that is to be demolished

The person responsible for the development site is to erect or install on or around the development area such temporary structures or appliances (wholly within the development site) as are necessary to protect persons or property and to prevent unauthorised access to the site in order for the land or premises to be maintained in a safe or healthy condition. Upon completion of the development, such temporary structures or appliances are to be removed within 7 days.

- (m) A "Road Opening Permit" must be obtained from Council, and all appropriate charges paid, prior to commencement of any work on Council property. The owner/applicant shall be responsible for all public utilities and services in the area of the work, shall notify all relevant Authorities, and bear all costs associated with any repairs and/or adjustments as those Authorities may deem necessary.
- (n) The works must comply with the relevant Ausgrid Network Standards and SafeWork NSW Codes of Practice.
- (o) Requirements for new swimming pools/spas or existing swimming pools/spas affected by building works.
 - (1) Child resistant fencing is to be provided to any swimming pool or lockable cover to any spa containing water and is to be consistent with the following;

Relevant legislative requirements and relevant Australian Standards (including but not limited) to:

- (i) Swimming Pools Act 1992
- (ii) Swimming Pools Amendment Act 2009
- (iii) Swimming Pools Regulation 2018
- (iv) Australian Standard AS1926 Swimming Pool Safety
- (v) Australian Standard AS1926.1 Part 1: Safety barriers for swimming pools

- (vi) Australian Standard AS1926.2 Part 2: Location of safety barriers for swimming pools.
- (2) A 'KEEP WATCH' pool safety and aquatic based emergency sign, issued by Royal Life Saving is to be displayed in a prominent position within the pool/spa area.
- (3) Filter backwash waters shall be conveyed to the Sydney Water sewerage system in sewered areas or managed on-site in unsewered areas in a manner that does not cause pollution, erosion or run off, is separate from the irrigation area for any wastewater system and is separate from any onsite stormwater management system.
- (4) Swimming pools and spas must be registered with the Division of Local Government.

Reason: To ensure that works do not interfere with reasonable amenity expectations of residents and the community.

FEES / CHARGES / CONTRIBUTIONS

7. Policy Controls

Northern Beaches Section 7.12 Contributions Plan 2022

A monetary contribution of \$2,420.00 is payable to Northern Beaches Council for the provision of local infrastructure and services pursuant to section 7.12 of the Environmental Planning & Assessment Act 1979 and the Northern Beaches Section 7.12 Contributions Plan (as amended).

The monetary contribution is based on a development cost of \$242,000.00.

The total amount payable will be adjusted at the time the payment is made, in accordance with the provisions of the Northern Beaches Section 7.12 Contributions Plan (as amended).

Details demonstrating compliance, by way of written receipts issued by Council, are to be submitted to the Certifier prior to issue of any Construction Certificate or, if relevant, the Subdivision Certificate (whichever occurs first).

A copy of the Contributions Plan is available for inspection at 725 Pittwater Road, Dee Why or on Council's website at Northern Beaches Council - Development Contributions.

Reason: To provide for contributions in accordance with the Contribution Plan to fund the provision of new or augmented local infrastructure and services.

8. Security Bond

A bond (determined from cost of works) of \$2,000 and an inspection fee in accordance with Council's Fees and Charges paid as security are required to ensure the rectification of any damage that may occur to the Council infrastructure contained within the road reserve adjoining the site as a result of construction or the transportation of materials and equipment to and from the development site.

An inspection fee in accordance with Council adopted fees and charges (at the time of payment) is payable for each kerb inspection as determined by Council (minimum (1) one inspection).

All bonds and fees shall be deposited with Council prior to Construction Certificate or demolition work commencing, and details demonstrating payment are to be submitted to the Certifier prior to the issue of the Construction Certificate.

To process the inspection fee and bond payment a Bond Lodgement Form must be completed with the payments (a copy of the form is attached to this consent and alternatively a copy is located on Council's website at www.northernbeaches.nsw.gov.au).

Reason: To ensure adequate protection of Council's infrastructure.

BUILDING WORK – BEFORE ISSUE OF A CONSTRUCTION CERTIFICATE

9. No Clearing of Vegetation

Unless otherwise exempt, no vegetation is to be cleared prior to issue of a Construction Certificate.

Details demonstrating compliance are to be submitted to the Certifier prior to issue of Construction Certificate.

Reason: To protect native vegetation.

10. Stormwater Drainage Disposal

The stormwater drainage systems for the development are to be designed, installed and maintained in accordance with Council's Water Management for Development Policy.

All stormwater drainage systems must comply with the requirements of Council's Water Management for Development Policy. Any recommendations identified within a Geotechnical Report relevant to the development are to be incorporated into the design of the stormwater drainage system. Details demonstrating compliance from a qualified and practising Civil Engineer and where relevant a Geotechnical Engineer must be submitted to and approved by the Certifier prior to the issue of a Construction Certificate.

When the proposed discharge point for the development in this consent cannot strictly comply with the Water Management for Development Policy, the Applicant must apply to verify the proposed discharge point by gaining Council approval via a Stormwater Drainage Application. Council approval must be provided to the Certifier prior to the issue of a Construction Certificate when a Stormwater Drainage Application is required. The Stormwater Drainage Application form can be found on Council's website.

Compliance with this condition must not result in variations to the approved development or additional tree removal.

Reason: To ensure satisfactory management of stormwater.

11. Installation and Maintenance of Sediment Control

Prior to any works commencing on site, including demolition, an erosion and sediment control plan must be prepared by a suitably qualified person in accordance with the following documents and provided to the Principal Certifier:

1. Council's relevant development control plan,

2. The guidelines set out in the NSW Department of Housing manual 'Managing Urban Stormwater: Soils and Construction Certificate' (the Blue Book) (as amended from time to time), and
3. The 'Do it Right On-Site, Soil and Water Management for the Construction Industry' (Southern Sydney Regional Organisation of Councils and the Natural Heritage Trust) (as amended from time to time).

Techniques used for erosion and sediment control on site are to be adequately maintained and monitored at all times, particularly after periods of rain, and shall remain in proper operation until all development activities have been completed and the site is sufficiently stabilised with vegetation.

Reason: To ensure no substance other than rainwater enters the stormwater system and waterways.

12. Compliance with standards (Demolition):

The development is required to be carried out in accordance with all relevant Australian Standards.

Details demonstrating compliance with the relevant Australian Standard are to be submitted to Council prior to the commencement of demolition works.

Reason: To ensure the development is constructed in accordance with appropriate standards.

13. Compliance with Standards

The development is required to be carried out in accordance with all relevant Australian Standards.

Details demonstrating compliance with the relevant Australian Standard are to be submitted to the Certifier prior to the issue of the Construction Certificate.

Reason: To ensure the development is constructed in accordance with appropriate standards.

14. Traffic Management Plan (CTMP)

A Construction Traffic Management Plan (CTMP) and report shall be prepared by a suitably qualified person and submitted to the Northern Beaches Council prior to issue of any Construction Certificate.

The CTMP must address following:

1. Demonstrate that Abernethy Street will not be impacted by the development, and where impacted, how the impacts will be mitigated to ensure traffic flow at all times during construction.

A copy of the approved CTMP must be kept on-site at all times while work is being carried out.

Reason: To ensure public safety and minimise any impacts to the adjoining pedestrian and vehicular traffic systems.

DURING BUILDING WORK

15. Tree and Vegetation Protection

a) Existing trees and vegetation shall be retained and protected, including:

- i) all prescribed trees within the site, including trees and vegetation nominated for retention on the approved Reports and Plans,
- ii) all trees and vegetation located on adjoining properties,
- iii) all trees and vegetation within the road reserve.

b) Tree protection shall be undertaken as follows:

- i) tree protection shall be in accordance with AS4970-2009 Protection of trees on development sites, and any recommendations of an approved Arboricultural Impact Assessment, including sections 10, 11, and 12,
- ii) existing ground levels shall be maintained within the tree protection zone of trees to be retained, unless authorised by an Arborist/Project Arborist with minimum AQF Level 5 in arboriculture,
- iii) removal of existing tree roots at or >25mm (Ø) diameter is not permitted without consultation with an Arborist/Project Arborist with minimum AQF Level 5 in arboriculture,
- iv) no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,
- v) structures are to bridge tree roots at or >25mm (Ø) diameter unless directed by an Arborist/Project Arborist with minimum AQF Level 5 in arboriculture on site,
- vi) excavation for stormwater lines and all other utility services is not permitted within the tree protection zone, without consultation with an Arborist/Project Arborist with minimum AQF Level 5 in arboriculture including advice on root protection measures,
- vii) should either or all of v) or vi) occur during site establishment and construction works, an Arborist/Project Arborist with minimum AQF Level 5 in arboriculture shall provide recommendations for tree protection measures. Details including photographic evidence of works undertaken shall be submitted by the Arborist/Project Arborist to the Principal Certifier,
- viii) any temporary access to, or location of scaffolding within the tree protection zone of a protected tree or any other tree to be retained during the construction works is to be undertaken using the protection measures specified in sections 4.5.3 and 4.5.6 of AS4970-2009 Protection of trees on development sites,
- ix) the activities listed in section 4.2 of AS4970-2009 Protection of trees on development sites, shall not occur within the tree protection zone of any tree on the lot or any tree on an adjoining site,
- x) tree pruning from within the site to enable approved works shall not exceed 10% of any tree canopy, and shall be in accordance with AS4373-2007 Pruning of amenity trees,
- xi) the tree protection measures specified in this clause must: i) be in place before work commences on the site, and ii) be maintained in good condition during the construction period, and iii) remain in place for the duration of the construction works.

The Principal Certifier must ensure that:

- c) The arboricultural works listed in a) and b) are undertaken as complaint to AS4970-2009 Protection of trees on development sites, and any recommendations of an approved Arboricultural Impact Assessment and/or Project Arborist as applicable.

Reason: Tree and vegetation protection.

16. **Wildlife Protection**

If construction activity associated with this development results in injury or displacement of a native mammal, bird, reptile or amphibian, a licensed wildlife rescue and rehabilitation organisation must be contacted for advice.

Reason: To protect native wildlife.

17. **Protection of Habitat Features**

All natural landscape features, including any rock outcrops, native vegetation and/or watercourses, are to remain undisturbed during the construction works, except where affected by necessary works detailed on approved plans.

Reason: To protect wildlife habitat.

18. **Geotechnical Requirements**

All recommendations (if any) included in the Geotechnical Report referenced in Condition 1 of this consent are required to be complied with during works.

Reason: To ensure geotechnical risk is mitigated appropriately.

19. **Survey Certificate**

A survey certificate prepared by a Registered Surveyor is to be provided demonstrating all perimeter walls columns and or other structural elements, floor levels and the finished roof/ridge height are in accordance with the approved plans.

Details demonstrating compliance are to be submitted to the Principal Certifier when the external structure of the building is complete.

Reason: To demonstrate the proposal complies with the approved plans.

20. **Aboriginal Heritage**

If in undertaking excavations or works any Aboriginal site or object is, or is thought to have been found, all works are to cease immediately and the applicant is to contact the Aboriginal Heritage Officer for Northern Beaches Council, and the Cultural Heritage Division of the Department of Planning, Housing and Infrastructure.

Any work to a site that is discovered to be the location of an Aboriginal object, within the meaning of the National Parks and Wildlife Act 1974, requires a permit from the Director of the Department of Planning, Housing and Infrastructure.

Reason: Aboriginal Heritage Protection.

BEFORE ISSUE OF THE OCCUPATION CERTIFICATE

21. **No Weeds Imported On To The Site**

No Priority or environmental weeds (as specified in the Northern Beaches Local Weed Management Plan) are to be imported on to the site prior to or during construction works.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to issue of any Occupation Certificate.

Reason: To reduce the risk of site works contributing to spread of Priority and environmental weeds.

22. **Priority Weed Removal and Management**

All Priority weeds (as specified in the Northern Beaches Local Weed Management Plan) within the development footprint are to be removed using an appropriate control method.

Details demonstrating compliance are to be submitted to the Principal Certifier prior to issue of any Occupation Certificate.

Reason: To reduce the risk of site works contributing to spread of Priority weeds.

ON-GOING CONDITIONS THAT MUST BE COMPLIED WITH AT ALL TIMES

23. **Control of Domestic Dogs/Cats**

Domestic dogs and cats are to be kept from entering wildlife habitat areas at all times.

Dogs and cats are to be kept in an enclosed area and/or inside the dwelling, or on a leash such that they cannot enter areas of wildlife habitat, bushland or foreshore unrestrained, on the site or on surrounding properties or reserves.

Reason: To protect native wildlife and habitat.

24. **Geotechnical Recommendations**

Any ongoing recommendations of the risk assessment required to manage the hazards identified in the Geotechnical Report referenced in Condition 1 of this consent are to be maintained and adhered to for the life of the development.

Reason: To ensure geotechnical risk is mitigated appropriately.

25. **Lift/Elevator Motor Noise**

The Lift / Elevator motor shall not produce noise levels that exceed 5dBA above the background noise when measured from the nearest property boundary.

Reason: To ensure that the development does not impact on the acoustic privacy of surrounding residential properties.

In signing this report, I declare that I do not have a Conflict of Interest.

Signed



Reeve Cocks, Planner

The application is determined on //, under the delegated authority of:



Rodney Piggott, Manager Development Assessments