

## Engineering Referral Response

<b>Application Number:</b>	DA2021/0045
<b>Date:</b>	30/09/2021
<b>To:</b>	Kent Bull
<b>Land to be developed (Address):</b>	Lot 1 DP 88028 , 77 Bassett Street MONA VALE NSW 2103 Lot 4 DP 707291 , 77 Bassett Street MONA VALE NSW 2103

### Reasons for referral

This application seeks consent for the following:

- New Dwellings or
- Applications that require OSD where additional impervious area exceeds 50m<sup>2</sup> or
- Alterations to existing or new driveways or
- Where proposals affect or are adjacent to Council drainage infrastructure incl. watercourses and drainage channels or
- Torrens, Stratum and Community Title Subdivisions or
- All new Commercial and Industrial and RFB Development with the exception of signage or
- Works/uses in flood affected areas

And as such, Council's development engineers are required to consider the likely impacts on drainage regimes.

### Officer comments

The subject site is burdened by a Council drainage easement and pipelines which may be impacted as part of the proposed works. In this regard, the applicant is required to demonstrate compliance with Council's Water Management Policy Clause 6.1. This consists of accurately locating, confirming dimensions and plotting Council's stormwater pipelines and associated infrastructure to scale on the DA plans which show the proposed works. This should be carried out by a service locating contractor and registered surveyor. (The applicant will need to provide evidence of the methodology used for locating). A plan outlining the indicative locations of Council's stormwater infrastructure is available from Council's website. Northern Beaches Council has public stormwater drainage maps online. Please follow the relevant link below and select the 'Stormwater' map from the 'No Overlay Map' drop down menu. You can then search by address and use the zoom functionality to see pipe diameters and asset id numbers.

<https://services.northernbeaches.nsw.gov.au/icongis/index.html>

Development Engineers cannot support the proposal due to insufficient information to assess Clause B5.15 of Pittwater DCP.

### Additional information submitted 17/09/2021

The submitted information and amended plans satisfy the requirements of the DCP.

No objection to the proposal, subject to conditions as recommended.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

**Recommended Engineering Conditions:**

**CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE**

**Stormwater Disposal**

The applicant is to submit Stormwater Engineering Plans for the new development within this development consent, prepared by an appropriately qualified and practicing Civil Engineer, indicating all details relevant to the collection and disposal of stormwater from the proposed awning structure, paved areas and where appropriate adjacent catchments. Stormwater shall be conveyed from the site to the existing drainage system on the site.

Details demonstrating compliance are to be submitted to the Certifying Authority for approval prior to the issue of the Construction Certificate.

Reason: To ensure appropriate provision for disposal and stormwater management arising from the development.

**Structural Adequacy and Excavation Work**

Excavation work is to ensure the stability of the soil material of adjoining properties, the protection of adjoining buildings, services, structures and / or public infrastructure from damage using underpinning, shoring, retaining walls and support where required. All retaining walls are to be structurally adequate for the intended purpose, designed and certified by a Structural Engineer, except where site conditions permit the following:

- (a) maximum height of 900mm above or below ground level and at least 900mm from any property boundary, and
- (b) Comply with AS3700, AS3600 and AS1170 and timber walls with AS1720 and AS1170.

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Construction Certificate.

Reason: To provide public and private safety.

**CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK**

**Road Reserve**

The applicant shall ensure the public footways and roadways adjacent to the site are maintained in a safe condition at all times during the course of the work.

Reason: Public safety.

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

**Stormwater Disposal**

The stormwater drainage works shall be certified as compliant with all relevant Australian Standards and Codes by a suitably qualified person. Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of the Occupation Certificate.

Reason: To ensure appropriate provision for the disposal of stormwater arising from the development.