BASIX Certificate

Building Sustainability Index www.basix.nsw.gov.au

Alterations and Additions

Certificate number: A350099 03

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Alterations and Additions Definitions" dated 06/10/2017 published by the Department. This document is available at www.basix.nsw.gov.au

Secretary

Date of issue: Thursday, 14, November 2019

To be valid, this certificate must be lodged within 3 months of the date of issue.



Project address Project name Lincoln DA 03 10 Lincoln Avenue Collaroy 2097 Street address Northern Beaches Council Local Government Area Deposited Plan 16998 Plan type and number Lot number 14 Section number Project type Separate dwelling house Dwelling type Type of alteration and My renovation work is valued at \$50,000 or more, addition and includes a pool (and/or spa).

Certificate Prepared by (please complete before submitting to Council or PCA)

Name / Company Name: CM Studio

ABN (if applicable): 158240996

escriptio

Pool and Spa	Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Outdoor swimming pool	_		
The swimming pool must be outdoors.	~	✓	✓
The swimming pool must not have a capacity greater than 39.99 kilolitres.	✓	✓	✓
The swimming pool must have a pool cover.		✓	✓
The applicant must install a pool pump timer for the swimming pool.		✓	✓
The applicant must not incorporate any heating system for the swimming pool that is part of this development.		✓	✓

Fixtures and systems	Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Hot water			
The applicant must install the following hot water system in the development: gas instantaneous.	✓	V	✓
Lighting		1	
The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light-emitting-diode (LED) lamps.		~	✓
Fixtures		1	
The applicant must ensure new or altered showerheads have a flow rate no greater than 9 litres per minute or a 3 star water rating.		✓	✓
The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating.		✓	✓
The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating.		✓	

BASIX Certificate number: A350099_03 page 4 / 9

Construction			Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Insulation requirements					
	ation is not required where the area of new con	fs) in accordance with the specifications listed in struction is less than 2m2, b) insulation specified	V	V	✓
Construction	Additional insulation required (R-value)	Other specifications			
concrete slab on ground floor.	nil				
floor above existing dwelling or building.	nil				
external wall: framed (weatherboard, fibro, metal clad)	R1.30 (or R1.70 including construction)				
flat ceiling, pitched roof	ceiling: R1.75 (up), roof: foil/sarking	light (solar absorptance < 0.475)			
raked ceiling, pitched/skillion roof: framed	ceiling: R1.76 (up), roof: foil/sarking	light (solar absorptance < 0.475)			
flat ceiling, flat roof: framed	ceiling: R1.82 (up), roof: foil/sarking	light (solar absorptance < 0.475)			

Glazing requirements	Show on DA Plans	Show on CC/CDC Plans &	Certifier Check
		specs	
Windows and glazed doors			
The applicant must install the windows, glazed doors and shading devices, in accordance with the specifications listed in the table below. Relevant overshadowing specifications must be satisfied for each window and glazed door.	~	~	~
The following requirements must also be satisfied in relation to each window and glazed door:		✓	✓
Each window or glazed door with standard aluminium or timber frames and single clear or toned glass may either match the description, or, have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below. Total system U-values and SHGCs must be calculated in accordance with National Fenestration Rating Council (NFRC) conditions.		✓	✓
Each window or glazed door with improved frames, or pyrolytic low-e glass, or clear/air gap/clear glazing, or toned/air gap/clear glazing must have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below. Total system U-values and SHGCs must be calculated in accordance with National Fenestration Rating Council (NFRC) conditions. The description is provided for information only. Alternative systems with complying U-value and SHGC may be substituted.		✓	~
For projections described in millimetres, the leading edge of each eave, pergola, verandah, balcony or awning must be no more than 500 mm above the head of the window or glazed door and no more than 2400 mm above the sill.	✓	✓	~
For projections described as a ratio, the ratio of the projection from the wall to the height above the window or glazed door sill must be at least that shown in the table below.	✓	✓	✓
Pergolas with polycarbonate roof or similar translucent material must have a shading coefficient of less than 0.35.		✓	✓
External louvres and blinds must fully shade the window or glazed door beside which they are situated when fully drawn or closed.		✓	✓
Pergolas with fixed battens must have battens parallel to the window or glazed door above which they are situated, unless the pergola also shades a perpendicular window. The spacing between battens must not be more than 50 mm.		✓	~
Overshadowing buildings or vegetation must be of the height and distance from the centre and the base of the window and glazed door, as specified in the 'overshadowing' column in the table below.	✓	✓	~
Windows and glazed doors glazing requirements			

Page 6 / 9

Glazing requirements						Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check	
Window / door no.	Orientation	Area of glass inc. frame (m2)	Oversha Height (m)	dowing Distance (m)	Shading device	Frame and glass type			
WG.01	S	8	0	0	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WG.02	W	2.5	0	0	external louvre/blind (adjustable)	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
WG.03	S	19	0	0	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WG.04	Е	2.5	0	0	external louvre/blind (adjustable)	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
WG.05	S	5	0	0	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WG.06	E	6.5	4	2.4	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WG.07	E	2.6	5	2.8	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WG.08	E	2.6	5	2.5	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WG.09	E	8	4	2.4	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WG.10	N	7	0	0	eave/verandah/pergola/balcony >=450 mm	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
WG.11	W	17	0	0	eave/verandah/pergola/balcony >=750 mm	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
WG.12	N	20	0	0	eave/verandah/pergola/balcony >=450 mm	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
WL1.01	S	2.5	0	0	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			

Glazing requirements						Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check	
Window / door	Orientation		Oversha	adowing	Shading device	Frame and glass type			
no.		glass inc. frame (m2)	Height (m)	Distance (m)					
WL1.02	S	5.5	0	0	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WL1.03	S	5.5	0	0	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WL1.04	S	5.5	0	0	none	standard aluminium, single clear, (or U-value: 7.63, SHGC: 0.75)			
WL1.05	N	5	0	0	projection/height above sill ratio >=0.23	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
WL1.06	N	2	0	0	projection/height above sill ratio >=0.23	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
WL1.07	N	2	0	0	projection/height above sill ratio >=0.23	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
WL1.08	N	5	0	0	projection/height above sill ratio >=0.23	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
WL1.09	E	3	0	0	awning (adjustable) >=900 mm	standard aluminium, single pyrolytic low-e, (U-value: 5.7, SHGC: 0.47)			
Skylights									<u> </u>
The applicant	must install th	e skylight	s in acco	rdance with t	he specifications listed in the table b	pelow.	✓	✓	✓
The following requirements must also be satisfied in relation to each skylight:					✓	✓			
Each skylight may either match the description, or, have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below.						✓	✓		
Skylights g	lazing requ	uiremen	ts						

Glazing require	Glazing requirements					
Skylight number	Area of glazing inc. frame (m2)	Shading device	Frame and glass type			
S1	1.99	no shading	timber, low-E internal/argon fill/clear external, (or U-value: 2.5, SHGC: 0.456)			
S2	1.99	no shading	timber, low-E internal/argon fill/clear external, (or U-value: 2.5, SHGC: 0.456)			

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a " " in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a "

"in the "Show on CC/CDC plans & specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.

Commitments identified with a "

"" in the "Certifier check" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate for the development may be issued.