

## Environmental Health Referral Response - industrial use

<b>Application Number:</b>	DA2021/0212
<b>Date:</b>	09/04/2021
<b>To:</b>	Lashta Haidari
<b>Land to be developed (Address):</b>	Lot 101 DP 1209504 , 5 Skyline Place FRENCHS FOREST NSW 2086

### Reasons for referral

This application seeks consent for large/and or industrial development.

And as such, Council's Environmental Investigations officers are required to consider the likely impacts.

### Officer comments

#### General Comments

Environmental Health support the proposal based on parameters such as noise and light emissions.

### Recommendation

APPROVAL - subject to conditions

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

### Recommended Environmental Investigations Conditions:

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE**

#### Mechanical Ventilation

Where mechanical ventilation is required to be installed in a food premises it must comply with Australian Standard (AS) 1668.2 "The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings" prior to any Occupation Certificate (OC) being issued.

Certification is to be provided to the Principal Certifying Authority by a suitably qualified person that the mechanical ventilation complies with the above requirements.

Reason: To ensure that the installed mechanical ventilation complies with the requirements of the Australian Standard 1668.2.