

Landscape Referral Response

Application Number:	DA2020/0193
Date:	09/03/2020
Responsible Officer:	Ashley Warnest
Land to be developed (Address):	Lot 51 DP 1043879 , 3 Bakers Road CHURCH POINT NSW 2105

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The proposal, in terms of landscape outcome, is acceptable subject to the protection of the existing trees and vegetation. The proposal is for the construction of alterations and additions to an existing dwelling including a new deck, a detached carport, external stairs, and paving along the north-western side boundary.

The proposal maintains the existing area of landscaping to satisfy the landscape outcomes of Pittwater 21 DCP, and no significant trees protected under Northern Beaches Council tree policies are to be removed.

Council's Landscape section has assessed the proposal against the following Pittwater 21 DCP Controls:

B4.22 Preservation of Trees and Bushland Vegetation

C1.1 Landscaping

D4 Church Point and Bayview Locality

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Landscape Conditions:

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Tree and vegetation protection

- a) Existing trees and vegetation shall be retained and protected, including:
- i) all trees and other vegetation within the site not approved for removal, excluding exempt vegetation under the relevant planning instruments of legislation,

- ii) all trees and vegetation located on adjoining properties,
- iii) all road reserve trees and vegetation.

b) Tree protection shall be generally undertaken as follows:

- i) all tree protection shall be in accordance with AS4970- 2009 Protection of Trees on Development Sites,
 - ii) removal of existing tree roots greater than 25mm is not permitted without consultation with a AQF Level 5 Arborist,
 - iii) existing ground levels shall remain under the tree protection zone of trees to be retained, unless authorised by AQF Level 5 Arborist,
 - iv) any tree roots exposed during excavation with a diameter greater than 25mm within the tree protection zone must be assessed by an AQF Level 5 Arborist. Details including photographic evidence of works undertaken shall be submitted to the Certifying Authority,
 - v) to minimise the impact on trees and vegetation to be retained and protected, no excavated material, building material storage, site facilities, nor landscape materials are to be placed within the canopy dripline of trees and other vegetation required to be retained,
 - vi) no tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a AQF Level 5 Project Arborist on site,
 - vii) all structures are to bridge tree roots greater than 25mm diameter unless directed by a AQF Level 5 Arborist on site,
 - viii) excavation for stormwater lines and all other utility services is not permitted within the tree protection zone, without consultation with a AQF Level 5 Arborist, including advice on root protection measures,
 - ix) should either or all of vi), vii) and viii) occur during site establishment and construction works, a AQF Level 5 Arborist shall provide recommendations for tree protection measures. Details including photographic evidence of works undertaken shall be submitted by the Arborist to the Certifying Authority,
 - x) tree pruning to enable construction shall not exceed 10% of any tree canopy, or in accordance with any site directions provided by a AQF Level 5 Arborist, and shall be in accordance with AS4373-2009 Pruning of Amenity Trees.
- c) All protected trees are to be retained for the life of the development, or for their safe natural life. Trees that die or are removed by approval must be replaced with a locally native canopy tree.

Reason: to retain and protect significant planting on development and adjoining sites.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Condition of retained vegetation

Prior to the issue of an Occupation Certificate, a report prepared by an Arborist with AQF minimum Level 5 qualifications in arboriculture/horticulture shall be submitted to the Certifying Authority, assessing the health and impact on all existing trees required to be retained, including the following information:

- i) compliance to any Arborist recommendations for tree protection and excavation works,
- ii) extent of damage sustained by vegetation as a result of the construction works,
- iii) any subsequent remedial works required to ensure the long term retention of the vegetation.

The Arborist is to be engaged at the commencement of works to record the condition of existing trees within 5 metres of development prior to any demolition and construction activity.

Reason: to retain and protect significant planting on development sites.