

Natural Environment Referral Response - Flood

Application Number:	DA2024/0537
Proposed Development:	Construction of a swimming pool
Date:	13/05/2024
To:	Reeve Cocks
Land to be developed (Address):	Lot 2 DP 1272873 , 31 B Bennett Street CURL CURL NSW 2096

Reasons for referral

This application seeks consent for the following:

- All Development Applications on land below the 1 in100 year flood level;
- All Development Applications located on land below the Probable Maximum Flood levels.

And as such, Council's Natural Environment Unit officers are required to consider the likely impacts on drainage regimes.

Officer comments

The proposal is for the construction of a new swimming pool.

Subject to the following conditions, the proposal complies with Section E11 of the Warringah DCP and Clause 5.21 of the Warringah LEP.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Natural Environment Conditions:

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Pools

The pool's coping is to be less than 150mm above natural ground level.

All electrical equipment associated with the pool (including pool pumps) is to be waterproofed and/or located at or above the Flood Planning Level of 5.61m AHD.

All chemicals associated with the pool are to be stored at or above the Flood Planning Level of 5.61m AHD.

Pool fencing shall be open to allow for the unimpeded movement of flood waters. It must be designed

with a minimum of 50% open area from the natural ground level up to the 1% AEP flood level of 5.61m AHD.

Details demonstrating compliance are to be submitted to the Principal Certifier for approval.

Reason: To reduce the impact of flooding and flood liability on owners and occupiers of flood-prone property and reduce public and private losses in accordance with Council and NSW Government policy.