18th May 2022



Project No. 7647000 Revision No. 01

Simon Ehrlich PO Box 587 Rose Bay NSW 2029

Attention: Mr Simon Ehrlich

Dear Simon,

RE: 167 Riverview Road, Avalon Civil Engineering Services

We are writing in response to the letter received on 12<sup>th</sup> April 2022, in regards to the 167 Riverview Road, Avalon property and specially to address the following comment from the Council's Natural Environment Unit officer:

"The application states that the stormwater system would connect to the existing system but insufficient evidence has been provided to support this. A stormwater management plan should be provided which includes details about the proposed stormwater system, what controls such as sediment pits will be in place for water quality, and whether the stormwater outlet into Pittwater is pre-existing or not. Note that new stormwater outlets to Pittwater generally require approval from the Natural Resources Access Regulator (NRAR)."

We have undertaken a visit of the property and confirmed the existence of a drainage system which discharges to the Pittwater at two (2) locations. Please find attached drawing C6.01 Issue 1 which illustrates the existing drainage system which contains two (2) existing connections to the Pittwater. Also illustrated is the proposed drainage system for the additions to the development. No new discharges to the Pittwater are proposed for the development. The design provides for a new sediment pit to address water quality issues. The design is deemed to be fit-for-purpose.

Should you require further information, please do not hesitate to contact the undersigned.

Yours faithfully, WARREN SMITH CONSULTING ENGINEERS

Michael Cahalane

Managing Director

Mobile: 0433 522 569

Email: <u>michael@warrensmith.com.au</u>

