

BASIX[®]Certificate

Building Sustainability Index www.basix.nsw.gov.au

Alterations and Additions

Certificate number: A329719_04

This certificate confirms that the proposed development will meet the NSW government's requirements for sustainability, if it is built in accordance with the commitments set out below. Terms used in this certificate, or in the commitments, have the meaning given by the document entitled "BASIX Alterations and Additions Definitions" dated 06/10/2017 published by the Department. This document is available at www.basix.nsw.gov.au

This certificate is a revision of certificate number A329719 lodged with the consent authority or certifier on 01 Oct 2018 with application DA2018/1616.

It is the responsibility of the applicant to verify with the consent authority that the original, or any revised certificate, complies with the requirements of Sch 1 Cl 2A, 4A or 6A of the Environmental Planning and Assessment Regulation 2000

Secretary

Date of issue: Tuesday, 21, April 2020

To be valid, this certificate must be lodged within 3 months of the date of issue.



Planning,
Industry &
Environment

Description of project

Project address	
Project name	Riverview 3_04
Street address	3 Riverview Road Avalon 2107
Local Government Area	Northern Beaches Council
Plan type and number	Deposited Plan 3632
Lot number	6
Section number	
Project type	
Dwelling type	Separate dwelling house
Type of alteration and addition	My renovation work is valued at \$50,000 or more, and includes a pool (and/or spa).

Certificate Prepared by (please complete before submitting to Council or PCA)

Name / Company Name: Delisle Hunt Wood Pty Ltd

ABN (if applicable): 631934837

Pool and Spa	Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Rainwater tank			
The applicant must install a rainwater tank of at least 1142 litres on the site. This rainwater tank must meet, and be installed in accordance with, the requirements of all applicable regulatory authorities.	✓	✓	✓
The applicant must configure the rainwater tank to collect rainwater runoff from at least 150 square metres of roof area.		✓	✓
The applicant must connect the rainwater tank to a tap located within 10 metres of the edge of the outdoor spa.		✓	✓
Outdoor spa			
The spa must not have a capacity greater than 3 kilolitres.	✓	✓	✓
The spa must have a spa cover.		✓	✓
The applicant must install a spa pump timer.		✓	✓
The applicant must install the following heating system for the outdoor spa that is part of this development: electric heat pump.		✓	✓

Fixtures and systems	Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Hot water			
The applicant must install the following hot water system in the development: gas instantaneous.	✓	✓	✓
Lighting			
The applicant must ensure a minimum of 40% of new or altered light fixtures are fitted with fluorescent, compact fluorescent, or light-emitting-diode (LED) lamps.		✓	✓
Fixtures			
The applicant must ensure new or altered showerheads have a flow rate no greater than 9 litres per minute or a 3 star water rating.		✓	✓
The applicant must ensure new or altered toilets have a flow rate no greater than 4 litres per average flush or a minimum 3 star water rating.		✓	✓
The applicant must ensure new or altered taps have a flow rate no greater than 9 litres per minute or minimum 3 star water rating.		✓	

Construction			Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Insulation requirements					
<p>The applicant must construct the new or altered construction (floor(s), walls, and ceilings/roofs) in accordance with the specifications listed in the table below, except that a) additional insulation is not required where the area of new construction is less than 2m², b) insulation specified is not required for parts of altered construction where insulation already exists.</p>			✓	✓	✓
Construction	Additional insulation required (R-value)	Other specifications			
concrete slab on ground floor with in-slab heating system.	R1.00 (slab edge)	in-slab heating system			
floor above existing dwelling or building.	nil				
external wall: other/undecided	R1.70 (including construction)				
raked ceiling, pitched/skillion roof: framed	ceiling: R1.74 (up), roof: foil backed blanket (55 mm)	medium (solar absorptance 0.475 - 0.70)			
flat ceiling, flat roof: concrete/plasterboard internal	ceiling: R0.43 (up), roof: 50 mm foil backed polystyrene board	medium (solar absorptance 0.475 - 0.70)			

Glazing requirements	Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Windows and glazed doors			
<p>The applicant must install the windows, glazed doors and shading devices, in accordance with the specifications listed in the table below. Relevant overshadowing specifications must be satisfied for each window and glazed door.</p>	✓	✓	✓
<p>The following requirements must also be satisfied in relation to each window and glazed door:</p>		✓	✓
<p>Each window or glazed door with standard aluminium or timber frames and single clear or toned glass may either match the description, or, have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below. Total system U-values and SHGCs must be calculated in accordance with National Fenestration Rating Council (NFRC) conditions.</p>		✓	✓
<p>Each window or glazed door with improved frames, or pyrolytic low-e glass, or clear/air gap/clear glazing, or toned/air gap/clear glazing must have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below. Total system U-values and SHGCs must be calculated in accordance with National Fenestration Rating Council (NFRC) conditions. The description is provided for information only. Alternative systems with complying U-value and SHGC may be substituted.</p>		✓	✓
<p>For projections described in millimetres, the leading edge of each eave, pergola, verandah, balcony or awning must be no more than 500 mm above the head of the window or glazed door and no more than 2400 mm above the sill.</p>	✓	✓	✓
<p>For projections described as a ratio, the ratio of the projection from the wall to the height above the window or glazed door sill must be at least that shown in the table below.</p>	✓	✓	✓
<p>Pergolas with polycarbonate roof or similar translucent material must have a shading coefficient of less than 0.35.</p>		✓	✓
<p>External louvres and blinds must fully shade the window or glazed door beside which they are situated when fully drawn or closed.</p>		✓	✓
<p>Pergolas with fixed battens must have battens parallel to the window or glazed door above which they are situated, unless the pergola also shades a perpendicular window. The spacing between battens must not be more than 50 mm.</p>		✓	✓
<p>Overshadowing buildings or vegetation must be of the height and distance from the centre and the base of the window and glazed door, as specified in the 'overshadowing' column in the table below.</p>	✓	✓	✓
Windows and glazed doors glazing requirements			

Glazing requirements							Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Window / door no.	Orientation	Area of glass inc. frame (m ²)	Overshadowing		Shading device	Frame and glass type			
			Height (m)	Distance (m)					
DG.05	S	3	14	6	none	improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75)			
W1.01	N	15.6	7.2	10.75	external louvre/blind (adjustable)	improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75)			
W1.02	W	24.4	0	0	external louvre/blind (adjustable)	improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75)			
D2.03	W	6	0	0	projection/height above sill ratio ≥ 0.36	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
D2.04	W	6	0	0	projection/height above sill ratio ≥ 0.36	standard aluminium, single toned, (or U-value: 7.57, SHGC: 0.57)			
D2.05	W	6	0	0	projection/height above sill ratio ≥ 0.36	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
D2.06	W	6	4.2	2.8	projection/height above sill ratio ≥ 0.36	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W2.01	W	8.6	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75)			
W2.02	W	3.7	0	0	external louvre/blind (adjustable)	improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75)			
W3.01	E	4.3	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			
W3.02	E	8.1	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			
W3.03	W	3.8	0	0	external louvre/blind (adjustable)	improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75)			
W3.04	W	5.1	0	0	projection/height above sill ratio ≥ 0.29	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			

Glazing requirements							Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Window / door no.	Orientation	Area of glass inc. frame (m2)	Overshadowing		Shading device	Frame and glass type			
			Height (m)	Distance (m)					
W3.05	N	13	0	0	projection/height above sill ratio ≥ 0.36	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.06	N	8.9	0	0	projection/height above sill ratio ≥ 0.36	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.07	N	8.9	0	0	projection/height above sill ratio ≥ 0.36	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.08	N	8.9	0	0	projection/height above sill ratio ≥ 0.36	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.09	W	10.1	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.10	W	2	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.11	W	4.3	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.12	W	8.5	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.13	W	4.1	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.14	W	4.2	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.15	N	8.6	2.9	9.6	projection/height above sill ratio ≥ 0.23	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.15 High	W	1.6	0	0	projection/height above sill ratio ≥ 0.36	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W3.16	N	8	0	0	projection/height above sill ratio ≥ 0.43	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			

Glazing requirements							Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Window / door no.	Orientation	Area of glass inc. frame (m2)	Overshadowing		Shading device	Frame and glass type			
			Height (m)	Distance (m)					
W4.03	E	1.2	20.2	35.5	projection/height above sill ratio ≥ 0.23	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W4.04	E	1.2	20.2	35.5	projection/height above sill ratio ≥ 0.23	improved aluminium, single toned, (U-value: 6.39, SHGC: 0.56)			
W4.05	E	1.2	0	0	projection/height above sill ratio ≥ 0.23	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			
W4.06	E	1.2	0	0	projection/height above sill ratio ≥ 0.23	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			
W4.07	E	1.2	0	0	projection/height above sill ratio ≥ 0.23	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			
W4.08	E	1.2	0	0	projection/height above sill ratio ≥ 0.23	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			
W4.01	E	0.6	0	0	eave/verandah/pergola/balcony ≥ 900 mm	improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75)			
W4.02	E	0.6	0	0	eave/verandah/pergola/balcony ≥ 900 mm	improved aluminium, single clear, (U-value: 6.44, SHGC: 0.75)			
Skylights									
The applicant must install the skylights in accordance with the specifications listed in the table below.							✓	✓	✓
The following requirements must also be satisfied in relation to each skylight:								✓	✓
Each skylight may either match the description, or, have a U-value and a Solar Heat Gain Coefficient (SHGC) no greater than that listed in the table below.								✓	✓
Skylights glazing requirements									

Glazing requirements				Show on DA Plans	Show on CC/CDC Plans & specs	Certifier Check
Skylight number	Area of glazing inc. frame (m2)	Shading device	Frame and glass type			
W3.16-18	4	no shading	timber, low-E internal/argon fill/clear external, (or U-value: 2.5, SHGC: 0.456)			
W3.19-20	2.7	no shading	timber, low-E internal/argon fill/clear external, (or U-value: 2.5, SHGC: 0.456)			
W3.30-33	2.5	no shading	timber, low-E internal/argon fill/clear external, (or U-value: 2.5, SHGC: 0.456)			
Glazed roofs						
The applicant must install the glazed roofs described in the table below, in accordance with the specifications listed in the table.				✓	✓	✓
The following requirements must also be satisfied in relation to each glazed roof:					✓	✓
Glazed roofs glazing requirements						
Glazed roof number	Area of glazing (m2)	Shading device	Glass type			
W3.21-29	23.5	no shading	improved aluminium, single pyrolytic low-e, (U-value: 4.48, SHGC: 0.46)			

Legend

In these commitments, "applicant" means the person carrying out the development.

Commitments identified with a "✓" in the "Show on DA plans" column must be shown on the plans accompanying the development application for the proposed development (if a development application is to be lodged for the proposed development).

Commitments identified with a "✓" in the "Show on CC/CDC plans & specs" column must be shown in the plans and specifications accompanying the application for a construction certificate / complying development certificate for the proposed development.

Commitments identified with a "✓" in the "Certifier check" column must be certified by a certifying authority as having been fulfilled, before a final occupation certificate for the development may be issued.