

Environmental Health Referral Response - commercial use

Application Number:	DA2024/0013
Proposed Development:	Alterations and additions to an existing community facility (North Narrabeen Surf Life Saving Club)
Date:	01/02/2024
To:	Claire Ryan
Land to be developed (Address):	Lot B DP 376822 , 219 - 227 Ocean Street NARRABEEN NSW 2101 Lot 1 DP 339162 , 219 - 227 Ocean Street NARRABEEN NSW 2101 Lot 2 DP 339162 , 219 - 227 Ocean Street NARRABEEN NSW 2101 Lot 6 DP 5768 , 219 - 227 Ocean Street NARRABEEN NSW 2101 Lot 8 DP 5768 , 219 - 227 Ocean Street NARRABEEN NSW 2101 Lot 1 DP 339162 , 225 - 227 Ocean Street NARRABEEN NSW 2101

Reasons for referral

This application seeks consent for one or more of the following:

- Food premises, or
- Backpackers/Boarding house, or
- Mortuary, or
- Skin penetration, accupuncture, tattoo, beauty salon, or
- Public pool

And as such, Council's Environmental Health and Protection officers are required to consider the likely impacts.

Officer comments General Comments

This application is seeking consent for alterations and additions to North Narrabeen Surf Life Saving Club building. this includes;

an extension to the northern side of the building to facilitate a larger meeting room, with kitchen and store, and a minor increase to the size of the existing gym.

Environmental Health can condition the application to comply with the Australian Standard 4674 therefore Environmental Health recommends approval subject to conditions.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Environmental Health and Protection Conditions:

**CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE
OCCUPATION CERTIFICATE**

Registration of food Business

The food business must be registered with the appropriate regulatory authority, prior to the Occupation Certificate being issued.

Reason: Food premises are required to be registered with the Appropriate Regulatory Authority.

Kitchen Design, construction and fit out of food premises certification

Prior to the issuing of any occupation certificate, certification is to be provided to the Principal Certifier by a suitably qualified person demonstrating that the design, construction and fit out of food premises kitchen is compliant with the requirements of AS 4674 Design, construction and fit out of food premises.

Reason: To ensure that the kitchen complies with Australian Standard design requirements.

Mechanical Ventilation certification

Where Mechanical ventilation is required to be installed in the food premises it must comply with the following:

- Australian Standard (AS) 1668.2 "The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings"; and
- Any external exhaust discharge must be above the roofline and discharged in a manner that is not likely to cause an amenity impact.

Certification is to be provided to the Principal Certifier prepared by a suitably qualified person to demonstrate that the mechanical ventilation complies with the above requirements.

Reason: To ensure that the installed mechanical ventilation complies with the requirements of the Australian Standard 1668.2 and to prevent amenity impacts.