

TELEPHONE: 0466 583 996
EMAIL: development@ausgrid.com.au
REFERENCE: TRIM 2017/31/364

ATTN: Northern Beaches Council

PO Box 82
Manly NSW 1655



24 Campbell St,
Haymarket NSW 2000
All mail to:
GPO Box 4009,
Sydney, NSW 2001
T: 131365
Web: ausgrid.com.au

Re: DA2023/1358 - 22 Central Avenue Manly - Alterations and Additions to Existing Mixed Use Building (Loading Area).

I refer to Northern Beaches Council development application DA2023/1358.

This letter is Ausgrid's response under clause 45(2) of the State Environmental planning Policy (Infrastructure) 2007.

The assessment and evaluation of environmental impacts for a new development consent (or where a development consent is modified) is undertaken in accordance with requirements of Section 79C of the Environmental Planning and Assessment Act 1979. One of the obligations upon consent authorities, such as local councils, is to consider the suitability of the site for the development which can include a consideration of whether the proposal is compatible with the surrounding land uses and the existing environment.

In this regard, Ausgrid requires that due consideration be given to the compatibility of proposed development with existing Ausgrid infrastructure, particularly in relation to risks of electrocution, fire risks, Electric & Magnetic Fields (EMFs), noise, visual amenity and other matters that may impact on Ausgrid or the development.

With Regard to: Alterations and Additions to Existing Mixed Use Building (Loading Area) at 22 Central Avenue Manly

- Plans - Master Set
- Plan - Survey
- Plans - Master Set

Ausgrid consents to the above mentioned development subject to the following conditions:-

Proximity to Existing Network Assets

Underground Cables

There are existing underground electricity network Transmission and distribution assets in Central Avenue .

Special care should also be taken to ensure that driveways and any other construction activities within the footpath area do not interfere with the existing cables in the footpath. Ausgrid cannot guarantee the depth of cables due to possible changes in ground levels from previous activities after the cables were installed. Hence it is recommended that the developer locate and record the depth of all known underground services prior to any excavation in the area.

Safework Australia – Excavation Code of Practice, and Ausgrid's Network Standard NS156 outlines the minimum requirements for working around Ausgrid's underground cables.

Substation

There are existing electricity substation S15902 within 22 Central Avenue .

The existing electricity chamber substation may be impacted by the proposed construction. This type of building is susceptible to damage from subsidence or vibration due to nearby excavation or piling, and also due to building materials and machinery coming into contact with the facade of the building. The use of ground anchors under a substation building is generally not permitted due to the presence of underground cabling and earthing conductors which may be more than 10m deep. A further area of exclusion may be required in some circumstances.

The substation ventilation openings, including substation duct openings and louvered panels, must be separated from building air intake and exhaust openings, natural ventilation openings and boundaries of adjacent allotments, by separation distances which meet the requirements of all relevant authorities, building regulations, BCA and Australian Standards including AS 1668.2: The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings.

In addition to above, Ausgrid requires the substation ventilation openings, including duct openings and louvered panels, to be separated from building ventilation system air intake and exhaust openings, including those on buildings on adjacent allotments, by not less than 6 metres.

Exterior parts of buildings within 3 metres in any direction from substation ventilation openings, including duct openings and louvered panels, must have a fire rating level (FRL) of not less than 180/180/180 where the substation contains oil-filled equipment, or 120/120/120 where there is no oil filled equipment and be constructed of non-combustible material.

The development must comply with both the Reference Levels and the precautionary requirements of the ICNIRP Guidelines for Limiting Exposure to Time-varying Electric and Magnetic Fields (1 HZ – 100 kHz) (ICNIRP 2010).

For further details on fire segregation requirements refer to Ausgrid's Network Standard 113.

Existing Ausgrid easements, leases and/or right of ways must be maintained at all times to ensure 24 hour access. No temporary or permanent alterations to this property tenure can occur without written approval from Ausgrid.

For further details refer to Ausgrid's Network Standard 143.

Please do not hesitate to contact Wei Yao on Ph: 0466 583 996 (please quote our ref: Trim 2017/31/364) should you require any further information.

Regards,

Wei Yao
Asset Protection Officer

