

Building Assessment Referral Response

Application Number:	DA2019/1072
Date:	23/04/2020
To:	Renee Ezzy
Land to be developed (Address):	Lot 1 DP 219265 , 1797 Pittwater Road MONA VALE NSW 2103 Lot 2 DP 219265 , 38 Park Street MONA VALE NSW 2103 Lot 4 DP 76695 , 1795 Pittwater Road MONA VALE NSW 2103

Reasons for referral

This application seeks consent for Class 2-9 Buildings (i.e. all buildings except a dwelling, garage, shed, gazebo or swimming pool/spa) which include:

- Alterations and Additions; or
- Change of Use

And as such, Councils Building Assessment officers are required to consider the likely impacts.

Officer comments

The application has been investigated with respects to aspects relevant to the Building Certification and Fire Safety Department. There are no objections to approval of the development subject to inclusion of the attached conditions of approval and consideration of the notes below.

Note: The proposed development may not comply with some requirements of the BCA and the Premises Standards. Issues such as this however may be determined at Construction Certificate Stage.

The proposal is therefore supported.

Note: Should you have any concerns with the referral comments above, please discuss these with the Responsible Officer.

Recommended Building Assessment Conditions

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF THE CONSTRUCTION CERTIFICATE

Access and Egress - Basement Car Park

The proposed basement car park is required to comply with Part D 1.2 of the Building Code of Australia – 'Access and Egress' in that a second pedestrian exit as required to be provided.

Details demonstrating compliance are to be provided to the Certifying Authority prior to the issue of the Construction Certificate.

Reason: To ensure adequate provision is made for Access & Egress and building occupant health and safety.