

Landscape Referral Response

Application Number:	DA2019/1002
Date:	27/09/2019
Responsible Officer:	Megan Surtees
Land to be developed (Address):	Lot 108 DP 24360 , 3 Lumeah Avenue ELANORA HEIGHTS NSW 2101

Reasons for referral

This application seeks consent for the following:

- Construction / development works within 5 metres of a tree or
- New residential works with three or more dwellings. (RFB's, townhouses, seniors living, guesthouses, etc). or
- Mixed use developments containing three or more residential dwellings.
- New Dwellings or

Officer comments

The development application seeks approval for the construction of a secondary dwelling and associated works. The removal of a tree in the rear yard to locate the Secondary dwelling is noted. The proposal in terms of landscape outcome is acceptable subject to conditions.

Council's Landscape section has assessed the proposal against Pittwater 21 DCP Controls:

C1.1 Landscaping

D5 Elanora Heights Locality

D5.9 Landscaped Area - Environmentally Sensitive Land

Referral Body Recommendation

Recommended for approval, subject to conditions

Refusal comments

Recommended Landscape Conditions:

CONDITIONS THAT MUST BE ADDRESSED PRIOR TO ANY COMMENCEMENT

Tree protection

- (a) Existing trees which must be retained
 - i) All trees not indicated for removal on the approved plans, unless exempt under relevant planning instruments or legislation
 - ii) Trees located on adjoining land
- (b) Tree protection

- i) No tree roots greater than 25mm diameter are to be cut from protected trees unless authorised by a qualified Arborist on site.
- ii) All structures are to bridge tree roots greater than 25mm diameter unless directed otherwise by a qualified Arborist on site.
- iii) All tree protection to be in accordance with AS4970-2009 Protection of trees on development sites, with particular reference to Section 4 Tree Protection Measures.
- iv) All tree pruning within the subject site is to be in accordance with WDCP2011 Clause E1 Private Property Tree Management and AS 4373 Pruning of amenity trees
- v) All tree protection measures, including fencing, are to be in place prior to commencement of works.

Reason: To ensure compliance with the requirement to retain and protect significant planting on the site.

CONDITIONS TO BE COMPLIED WITH DURING DEMOLITION AND BUILDING WORK

Protection of rock and sites of significance

- a) All rock outcrops outside of the area of approved works are to be preserved and protected at all times during demolition excavation and construction works.
- b) Should any Aboriginal sites be uncovered during the carrying out of works, those works are to cease and Council, the NSW Office of Environment and Heritage (OEH) and the Metropolitan Local Aboriginal Land Council are to be contacted.

Reason: Preservation of significant environmental features.

CONDITIONS WHICH MUST BE COMPLIED WITH PRIOR TO THE ISSUE OF THE OCCUPATION CERTIFICATE

Required Planting

Trees shall be planted in accordance with the following schedule:

No. of Trees Required.	Species	Location	Pot Size
1	Tree species capable of attaining a minimum height of 5 metres at maturity	Grounds of property	200mm

Details demonstrating compliance are to be submitted to the Principal Certifying Authority prior to the issue of any interim / final Occupation Certificate.

Reason: To maintain environmental amenity.